NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 17115 within 30 days from the data of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED JAN2 5 1974 State Well No. STATE ENGINEER SALEM, OREGON Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name Ronald Baker	County Umatella, Driller's well number
Address P.O. B. 109	11. W 1/4 S. E 1/4 Section 24 T. 4 N. R. 27 E. W.M.
Demistor, Oregan 97838	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well □ Deepening ★ Reconditioning ★ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	
7	Depth at which water was first found ft.
Cable D Jetted D Domestic D Industrial D Municipal	Static level 90 ft. below land surface. Date /- 9-74
Dug Bored Irrigation Test Well State K S	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded	(10) WHILL LOC.
8 Diam. from 0 ft. to 11.5 ft. Gage .250	(12) WELL LOG: Diameter of well below casing
	Depth drilled 58 ft. Depth of completed well 133 ft.
"Diam from ft. to ft. Gage ft. Gage	Formation: Describe color, texture, grain size and structure of materials;
Diam, Irom	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? Yes Y No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
	Pub brown broken 95 115
	Rack braum. 115 153 W.B.
perforations fromft. toft.	A POR , APOSOT
perforations fromft. toft.	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? ☐ Yes 🔯 No	
Manufacturer's Name	
TypeModel No	
Diam. Slot size Set from ft. to ft.	
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes ➡ No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
" " "	The second of th
Tur III	
Batter test 140 gal./min. with 25 ft. drawdown after / hrs.	
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	Work started /- 7 1974 Completed /- 4 1974
(A) CONCEDITON.	Date well drilling machine moved off of well 1974
(9) CONSTRUCTION:	Drilling Machine Operator's Certification:
Well seal-Material used AH disturbed	This well was constructed under my direct supervision.
Well sealed from land surface toft.	Materials used and information reported above are true to my
Diameter of well bore to bottom of seal in,	best knowledge and belief. [Signed]r
Diameter of well bore below sealin.	(Drillir Machine Operator)
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No
Number of sacks of bentonite used in well seal sacks	4
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of waterlbs./100 gals.	true to the best of my knowledge and belief.
Was a drive shoe used? Yes 🗆 No Plugs Size: location ft.	Name TROY GRIFFIM (Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Yes No	Address 900 HERMISTOM AVE, HERMISTOMO
Type of water? depth of strata	Address Addres
Method of sealing strata off	[Signed] Market (Water Well Contractor)
Was well gravel packed? Yes N. No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 65 Date