NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

UMAT 1757

# WATER WELL REPORT
## STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED JUN 18 1981 WATER RESOURCES DEPT SALEM, OREGON

State Well No. 4N/28E-3
State Permit No.

**(1) OWNER:**
Name Wayne Beck
Address Rt 1 Box 1980-B Hermiston Or. 97838

**(2) TYPE OF WORK (check):**
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

**(4) PROPOSED USE (check):**
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

**(5) CASING INSTALLED:** Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 36 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:** Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

**(7) SCREENS:** Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test Air 60 gal./min. with 50 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**
Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? Ran trimmy pipe pumped cement grout to land surface
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**
County Umatilla Driller's well number
¼ ¼ Section 03 T. 4N R. 28E W.M.
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**
Depth at which water was first found 94 ft.
Static level 24 ft. below land surface. Date 6-4-81
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:** Diameter of well below casing 6
Depth drilled 104 ft. Depth of completed well 104 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---|---|---|---|
| Surface sandy soil | 0 | 3 | |
| Sand Brown with boulders | 3 | 17 | |
| Clay yellow | 17 | 22 | |
| Clay green | 22 | 30 | |
| Rock brown soft | 30 | 50 | |
| Rock grey hard | 50 | 94 | 24 |
| Rock black soft | 94 | 104 | 24 |

Work started 6-4-81 19 Completed 6-4-81 19
Date well drilling machine moved off of well 6-4-81 19

**Drilling Machine Operator's Certification:**
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] W. R. Allison Date 6-4-81, 19
(Drilling Machine Operator)
Drilling Machine Operator's License No. 484

**Water Well Contractor's Certification:**
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Allison Drilling Co
(Person, firm or corporation) (Type or print)
Address Rt 3 Box 3447 Hermiston Or. 97838
[Signed] W. R. Allison
(Water Well Contractor)
Contractor's License No. 754 Date 6-4-81, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119