

WATER WELL REPORT
STATE OF OREGON

UMI.T
2084
2018

RECEIVED

DEC 13 1982

State Well No. 4W/28E-10C

PLEASE TYPE OR PRINT IN INK
WATER RESOURCES DEPT.
SALEM, OREGON

State Permit No.

(1) OWNER:

Name TROY GRIFFIN
Address 900 HERMISTON AVE
City HERMISTON State OR. 97838

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☒ Driven ☐ Domestic ☒ Industrial ☐ Municipal ☐
Rotary Mud ☐ Dug ☐ Irrigation ☐ Test Well ☐ Other ☐
☐ Bored ☐ Thermal: ☐ Withdrawal ☐ Reinjection ☐

(4) PROPOSED USE (check):

5) CASING INSTALLED:

Steel ☒ Plastic ☐
Threaded ☐ Welded ☒

6" Diam. from +1 ft. to 39 ft. Gauge 25
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Id: gal./min. with ft. drawdown after hrs.
" " " "

Air test 60 gal./min. with drill stem at 75 ft. 1 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☒

Well seal—Material used Cement

Well sealed from land surface to 39 ft.

Diameter of well bore to bottom of seal 10" to 20" Lower seal 8"

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 12 sacks

How was cement grout placed? Pressure grouted

Was pump installed? No Type HP Depth ft.

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of Water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel: ft.

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number
N.E. 1/4 S.W. 1/4 Section 10 T. 47N. R. 28E. W.M.

Tax Lot # Lot Blk Subdivision

Address at well location:

(11) WATER LEVEL: Completed well.

Depth at which water was first found 44 ft.

Static level 45 ft. below land surface. Date 11-19-82

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Sand	2	15	
Gravel & sand	15	34	
Rock, med. block	34	52	W.B.
Rock, black & blue claystone	52	64	W.B.
Rock, med. block	64	81	
Basalt, broken	81	100	W.B.

Work started 11-18 1982 Completed 11-19 1982

Date well drilling machine moved off of well 11-19 1982

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Troy Griffin Date 11-19, 1982

Bonded Water Well Constructor Certification:

Bond 1648428 Issued by: TRAVELERS
(number) Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name TROY GRIFFIN (Type or print)

Address 900 HERMISTON AVE. HERMISTON OR.

[Signed] Troy Griffin Water Well Constructor

Date 11-19, 1982

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*45292-690