

RECEIVED  
JAN 28 1966

10-P  
RECEIVED  
FEB 11 1966

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE ENGINEER  
SALEM OREGON

STATE OF OREGON  
SALEM OREGON  
(Please type or print)  
G-3629

State Well No. 4N/28-10P  
State Permit No. ....

UMAT  
2041

cca

(1) OWNER:  
Name Hermiston Medical Center  
Address 975 Orchard Ave.  
Hermiston, Ore.

(2) LOCATION OF WELL:  
County Umatilla Driller's well number  
1/4 1/4 Section 10 T. 4N R. 28E W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):  
Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic  Industrial  Municipal   
Irrigation  Test Well  Other  (5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED: Threaded  Welded   
8" Diam. from 0 ft. to 60 ft. Gage 330  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used  
Size of perforations in. by in.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.

(8) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name ..... Model No. ....  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:  
Well seal—Material used in seal Cement  
Depth of seal 18 ft. Was a packer used? no  
Diameter of well bore to bottom of seal 11 in.  
Were any loose strata cemented off?  Yes  No Depth .....  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.  
Did any strata contain unusuable water?  Yes  No  
Type of water? ..... depth of strata .....  
Method of sealing strata off .....

(10) WATER LEVELS:  
Static level 12 ft. below land surface Date 11-7-65  
Artesian pressure ..... lbs. per square inch Date .....

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Contractor  
Yield: 85 gal./min. with 180 ft. drawdown after 2 hrs.  
" " " " "  
" " " " "

Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well below casing 8  
Depth drilled 207 ft. Depth of completed well 207 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sand & gravel	0	14
Clay brown	14	26
Sand & gravel	26	33
Clay blue	33	38
Sand & gravel	38	49
Clay blue	49	62
Rock blue soft (water 60 G.P.M)	62	75
Rock gray hard	75	192
Rock black soft (water 25 G.P.M)	192	199
Clay blue sandy	199	203
Rock black medium	203	207

Work started 9-20-65. Completed 11-7-65 19  
Date well drilling machine moved off of well 11-7-65 19

(13) PUMP:  
Manufacturer's Name .....  
Type: ..... H.P. ....  
Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME Ben Drayer Drilling Contractor  
(Person, firm or corporation) (Type or print)  
Address Rt. 1 Bx 225 Hermiston, Ore.

Drilling Machine Operator's License No. 7  
[Signed] Ben Drayer  
(Water Well Contractor)  
Contractor's License No. 12 Date 11-7-65 19