

RECEIVED
MAY 17 1967
STATE ENGINEER
SALEM OREGON

42/28-11
State Permit No.

UMAT
2063

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON STATE ENGINEER
(Please type or print)

(1) OWNER:

Name Leonard N. & June Crume
Address 445 E. Jennie Ave.
Hermiston, Oregon

(2) LOCATION OF WELL:

County Umatilla Driller's well number
1/4 Section 11 T. 4N R. 28 E.W.M.
Bearing and distance from section or subdivision corner
W690' of S 2 of NE 4 of NW 4

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 32 ft. Threaded Welded Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal bentonite
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 11 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 6 ft. below land surface Date 5/10/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 20 gal./min. with 10ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 32 ft. Depth of completed well 32 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|--------------------|------|----|
| Sandy soil | 0 | 5 |
| Fine gravel | 5 | 14 |
| Clay, brown | 14 | 23 |
| Fine gravel & sand | 23 | 30 |
| Sand - water | 30 | 32 |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

Work started May 8 1967 Completed May 10 1967
Date well drilling machine moved off of well May 10 1967

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Hershey Well Drilling
(Person, firm or corporation) (Type or print)
Address Rt 1, Box 552, Hermiston, Oregon

Drilling Machine Operator's License No. 143
[Signed] John Hershey
(Water Well Contractor)
Contractor's License No. 315 Date 11 May 1967