

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

AUG 3 1965 WATER WELL REPORT

State Well No. 4N/28-11G

STATE ENGINEER, SALEM, OREGON ENGINEER OF OREGON within 30 days from the date of well completion. SALEM OREGON (Please type or print)

State Permit No. G3211

(1) OWNER:

Name Al Fowler Address Hermiston Oregon

UMAT 2067

(2) LOCATION OF WELL:

County Umatilla Driller's well number 11 T. 4 N R. 28 E, W.M. Bearing and distance from section or subdivision corner

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? Yield: gal./min. with ft. drawdown after hrs. Bailer test 70 gal./min. with 10 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made?

(12) WELL LOG:

Diameter of well below casing 8" Depth drilled 110 ft. Depth of completed well 110 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Entries include Sand, Clay mixed with gravel, Black rock-med hard, Black rock-Hard, Soft porous rock, Med Hard Black rock, Hard rock.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 30 ft. Gage 250

(7) PERFORATIONS:

Perforated? Yes No. Type of perforator used. Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No. Manufacturer's Name. Type Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal Clay. Depth of seal 30 ft. Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? Was a drive shoe used? Was well gravel packed? Gravel placed from ft. to ft. Did any strata contain unusable water? Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 7-26-65 Artesian pressure lbs. per square inch Date

Work started 7-7 1965 Completed 7-26 1965 Date well drilling machine moved off of well 7-27 1965

(13) PUMP:

Manufacturer's Name. Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME TROY GRIFFIN (Person, firm or corporation) Address 881 HERMISTON AVE, HERMISTON

Drilling Machine Operator's License No. 15

[Signed] Troy Griffin (Water Well Contractor)

Contractor's License No. 65 Date 7-29 1965