

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion.

**RECEIVED**  
 JUN 18 1969  
**STATE ENGINEER**  
**SALEM OREGON**

**WATER WELL REPORT**  
 STATE OF OREGON  
 (Please type or print)  
 (Do not write above this line)

**UMAT**  
 235

State Well No. 5/33-126

State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name FRANCO STUBBLEFIELD  
 Address P.O. Box 157, UKIAH, ORE. 97880

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Cable  Dug  Driven  Jetted  Bored  Domestic  Industrial  Municipal  Irrigation  Test Well  Other

**(4) CASING INSTALLED:**

Threaded  Welded   
 6" Diam. from 0 ft. to 116 ft. Gage 250  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**PERFORATIONS:**

Perforated?  Yes  No.  
 Type of perforator used \_\_\_\_\_  
 Size of perforations in. by in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WATER LEVEL: Completed well.**

Static level SURFACE 0 ft. below land surface Date 6-9-69  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level.  
 Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: Approx 150 gal./min. with  Rotary ft. drawdown after  2 1/2  hrs.  
 " " " " " " " " " " " "  
 " " " " " " " " " " " "  
 Baller test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
 Temperature of water 69° Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used CEMENT  
 Depth of seal 116' ft.  
 Diameter of well bore to bottom of seal 8 in.  
 Were any loose strata cemented off?  Yes  No Depth  ~~116'~~   
 Was a drive shoe used?  Yes  No  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(11) LOCATION OF WELL:**

County UMATILLA Driller's well number \_\_\_\_\_  
N.W. 1/4 Section 12 T. 55 R. 33E W.M.  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6"  
 Depth drilled 240 ft. Depth of completed well 240 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
BROKEN BROWN BASALT	1	24	
DECOMPOSED BROWN ROCK	24	26	
BROKEN GRAY BASALT	26	30	
DECOMPOSED BROWN ROCK	30	34	
BROKEN GRAY BASALT	34	39	
DECOMPOSED BROWN ROCK	39	42	
BROKEN BROWN BASALT	42	56	
DECOMPOSED BROWN ROCK	56	67	
BROWN BENTONITE & BROWN & BLACK BENTONITE	67	71	
BLUE CLAY (SOME WATER)	71	81	
BROKEN BROWN BASALT & RED BROWN BENTONITE	81	84	
BLUE CLAY	84	90	
GRAY CLAY	90	102	
BROKEN GRAY BASALT	102	108	
GRAY BASALT	108	156	25'
BROKEN GRAY BASALT (WATER)	156	169	
BROKEN BROWN BASALT (GREEN BENT.)	169	183	
BROKEN GRAY BASALT & GREEN BENTONITE	183	198	
BLACK BENTONITE & GIBSON BENTONITE	198	204	
BLACK HONEYCOMB & BROWN BENTONITE	204	214	
GRAY BASALT & IRON PYRITE	214	223	
BROKEN GRAY BASALT	223	228	
BROKEN BROWN BASALT (WATER)	228	235	
BLACK BASALT	235	240	SURFACE

Work started 6-4 1969 Completed 6-2 1969  
 Date well drilling machine moved off of well 6-9 1969

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
 [Signed] Paul W. Davis Date 6/11, 1969  
 (Drilling Machine Operator)  
 Drilling Machine Operator's License No. 147

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 NAME Paul W. Davis (Person, firm or corporation) (Type or print)  
 Address P.O. Box 162 M-J Jones  
 [Signed] Paul W. Davis (Water Well Contractor)  
 Contractor's License No. 159 Date 6/11, 1969