

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

UMAT 2420 WATER WELL REPORT

STATE OF OREGON MAR-7-1977 State Well No. 441/28E-2065

(Please type or print)

(Do not write above this line)

WATER RESOURCES DEPT. SALEM, OREGON

State Permit No.

(1) OWNER:

Name LeRue W Pollock Address Highway 30 Hermiston

(2) TYPE OF WORK (check):

New Well [ ] Deepening [x] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Drilled [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

(10) LOCATION OF WELL:

County Wmca Driller's well number 352 NW 1/4 NW 1/4 Section 20 T. 14N. R. 28 E W.M. Bearing and distance from section or subdivision corner SW corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found ft. Static level 26 ft. below land surface. Date Feb 24 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing ft. Depth drilled ft. Depth of completed well ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include gravel, clay blue, clay brown, clay yellow, gravel, gravel 1/2", packed rock, basalt.

Work started Feb 4 19 77 Completed Feb 24 19 77 Date well drilling machine moved off of well Feb 24 19 77

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] J. R. Fredrickson Date Feb 23, 19 77 Drilling Machine Operator's License No. B 52

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name J. R. Fredrickson Address RT 2 Box 2066 [Signed] J. R. Fredrickson Contractor's License No. 635 Date Feb 24 19 77

(5) CASING INSTALLED:

Threaded [ ] Welded [x] 16" Diam. from -9 ft. to 120 ft. Gage 250

(6) PERFORATIONS:

Perforated? [x] Yes [ ] No. Type of perforator used TOPCK Size of perforations 4 in. by 6 in. 110 perforations from 27 ft. to 105 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [ ] Yes [x] No If yes, by whom? Id: gal./min. with ft. drawdown after hrs.

(9) CONSTRUCTION:

Well seal—Material used cement Well sealed from land surface to 9 to 27 ft. Diameter of well bore to bottom of seal 30 in. Diameter of well bore below seal 16 in. Number of sacks of cement used in well seal 12 1/2 sacks Brand name of bentonite Number of pounds of bentonite per 100 gallons of water Was a drive shoe used? [x] Yes [ ] No Plugs Size: location ft. Did any strata contain unusable water? [ ] Yes [x] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [x] Yes [ ] No Size of gravel: 3" to 6" Gravel placed from 27 ft. to 30 ft.