

RECEIVED
JUL 25 1958

UMAT 2501

UMAT
2501

4N/28-22

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON

State Well No.

State Permit No.

(1) OWNER:

Name PENDLETON GRAIN GROWERS
Address Pendleton, Oregon

(2) LOCATION OF WELL:

County _____ Owner's number, if any—
1/4 SE 1/4 Section 22 T. 4 N R. 28 E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

8" Diam. from 0 ft. to 144 ft. Gage Standard

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
SIZE of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 144 ft.
Material used in seal— Steel shoe set in rock
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 107 ft. below land surface Date 7/18/58
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____
[Signed] Pendleton Grain Growers Inc Date 7-23, 1958
(Owner) Al Bauer - Asst Sec.

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? contractor
Yield: 226 gal./min. with 17 ft. drawdown after 4 hrs.
" " " " "
" " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.

Depth drilled 170 ft. Depth of completed well 170 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Fine sand	0	24
Gravel & sand cemented	24	115
Fine sand & gravel (cavey some water)	115	117
Sandy brown clay	117	125
Fine sand & gravel & blue clay	125	133
Broken brown & black rock (water bearing)	133	148
Blue clay, sand & gravel	148	170

Work started 7/3/58 19 Completed 7/19/58 19

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME D. K. SMITH
(Person, firm, or corporation) (Type or print)

Address Route 3, Walla Walla, Washington

Driller's well number _____

[Signed] D.K. Smith
(Well Driller)

License No. 204 Date 7/21/58, 19.....