

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion.

UMAT

2578

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

NOV 5 1976

State Well No.

State Permit No.

(1) OWNER:

Name J.R. Simpler Co.Address P.O. Box 1059
Caldwell, Idaho 83605

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☒ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒

12" Diam. from 0 ft. to 198 ft. Gage 375
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in, by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No. If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Pump test 400 gal./min. with 82 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 75 ft.

Diameter of well bore to bottom of seal 16 in.

Diameter of well bore below seal 12 in.

Number of sacks of cement used in well seal 84 sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons

of water lbs./100 gals.

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number

S.E. 1/4 S.W. 1/4 Section 27 T. 47N. R. 28E. W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 161 ft.

Static level 118 ft. below land surface. Date 10/26/76

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 230 ft. Depth of completed well 230 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	3	
Sand + Claystone	3	25	
Claystone, yellow	25	57	
Claystone, hard	57	115	
Gravel	115	125	
Boulders	125	133	
Claystone + gravel	133	157	
Claystone, blue + sand	157	161	
Sand + gravel	161	186	W.B.
Gravel	186	203	W.B.
Gravel + brown claystone	203	225	W.B.
Rock, soft, black	225	230	

Work started 10-4 1976 Completed 10-26 1976

Date well drilling machine moved off of well 10-26 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] James T. Leidel Date 10-26, 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 665

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name TROY GRIFFIN
(Person, firm or corporation) (Type or print)Address 900 HERMISTON AVE HERMISTON ORE[Signed] Troy Griffin
(Water Well Contractor)

Contractor's License No. 65 Date 10-26, 1976

WELL IDENTIFICATION FORM

RECEIVED

Owner's

Well Number:

POD #2

CURRENT WELL OWNER:

FEB - 4 1998

Phone

(541) 567-9733

Name:

J.R. Simplot Company

WATER RESOURCES DEPT.

SALEM, OREGON

Mailing Address:

P.O. Box 850 / 79319 Simplot Rd.

City:

Hermiston

State:

Oregon

Zip:

97038

WELL LOCATION:

County:

Umatilla

Latitude:

UMAT
2578

Longitude:

Township:

4

(N) or S,

Range:

28

(E) or W

Section:

27

SE 1/4

SW 1/4

Tax Lot Number:

Street Address of Well (if different from above):

N/A

If a well report is available for this well, please attach a copy of it to this form and return. It is not necessary for you to complete the remainder of the form if the well report is attached. If a well report is not available, please complete the remainder of the form to the best of your ability.

WELL INFORMATION:

Start Card Number:

UMAT-2578

Approx. Construction Date:

10-26-76

Well Constructor:

Troy Griffin

Name of Owner at Time of Construction:

J.R. Simplot Company

Well Depth (in feet):

230 ft.

Static Water Level (in feet):

118 ft

Diameter of Exposed Well Casing (in inches):

12 inches

Does this well have a formal water right associated with it? Yes: ☒ No: ☐ If yes:

Application #:

Permit #:

Certificate #:

W7322

Please Return Completed Form to:

Oregon Water Resources Department

158 12th Street NE

Salem, OR 97310

(Office use only)

Well Identification Number:

23259