UMAT 2596

WELL REPORTS 46 13 William ORIGINAL File Original and Duplicate with the STATE ENGINEER, SALEM, OREGON APR 3 () 1958 STE OF OREGON State Permit No. G-1-62 STATE ENGINEER (1) OWNER: Drawdown is amount water level is lowered below static level (11) WELL TESTS: William T. TUSALEN, OREGON Name Was a pump test made? MYes DNo If yes, by whom? Driller General Delivery Yield: 1100 gal./min. with 6 ft. drawdown after 24 Hermiston, Oregon (2) LOCATION OF WELL: Bailer test gal./min. with ft. drawdown after County Umatilla Owner's number, if any-Artesian flow g.p.m. Date T. 4 N R.28 E. W.M. NNEW NF. 4 Section 28 Temperature of water Was a chemical analysis made?

Yes X No Bearing and distance from section or subdivision corner <u>10 & 12</u> (12) WELL LOG: Depth drilled Depth of completed well Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation. MATERIAL Sa**h**d face TYPE OF WORK (check): 20 Coars**e** gravel 20 .₁ewi Well 🛱 Deepening 🗍 Reconditioning [115 Abandon 🗌 If abandonment, describe material and procedure in Item 11. Blue Clay 115 (4) PROPOSED USE (check): (5) TYPE OF WELL: Rotary | Driven mestic 🔲 Industrial 🗎 Municipal 🗆 Cable Jetted igation 🗗 Test Well 🗌 Other Bored (6) CASING INSTALLED: Threaded | Welded 40 ft. Gage 12 "Diam. from Surfacet to ft. to 120 ft. Gage 10 " Diam. from (7) PERFORATIONS: Perforated? X Yes No Type of perforator used SIZE of perforations in. by 2 perforations from 80 ft. to 115 perforations from ft. to ft. perforations from ______ft, to _____ perforations from ft. to ft. perforations from ft. to ft. 3) SCREENS: Well screen installed 🔲 Yes 🨾 No Jfacturer's Name Diam. Slot size Set from ft. to ft. Completed Feb 20. \ CONSTRUCTION: (13) PUMP: Worthington s well gravel packed? ☐ Yes Ano Size of gravel: Manufacturer's Name Gravel placed from _____ ft. to ____ ft. Type:Turbine H.P. 50 Was a surface seal provided? Tes No To what depth? Material used in seal-Well Driller's Statement: Did any strata contain unusable water?

Yes

No This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Type of water? Depth of strata Method of sealing strata off NAME L. H. Williams 2703 4th Street (10) WATER LEVELS: Static level ft. below land surface Date Driller's well number 1st completed well after licerise yas issued, // lbs. per square inch Date Artesian pressure Log Accepted by: [Signed]

License No.