NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report , are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

..(Do not write above this line)

State Well No.

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name Olen + Lois Lee	County Umatilla Driller's well number
Address Rt 3 Box 3220 B.	1W 14 N & 14 Section 6 T. 4 M R. 29 E. W.M.
Alemiston Oregon 97838	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check): U	
New Well Deepening Reconditioning Abandon Abandon	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found /8 ft.
Rotary M. Driven Domestic M. Industrial Municipal Domestic M. Domestic D. Dome	Static level 12 ft. below land surface. Date 2-5.80
□ Bored □ Irrigation □ Test Well □ Other □	Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well below casing 6"
6 "Diam from 1 ft to 54 ft Gage 256	Depth drilled 125 ft. Depth of completed well 125 ft.
"Diam. from ft. to ft. Gage ft. Gage ft. Gage	Formation: Describe color, texture, grain size and structure of materials;
Dialit. Holli	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
(6) PERFORATIONS: Perforated? ☐ Yes \$\forall No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	Topsvil 0 4
perforations from ft. to ft.	Skind gray 4 18
perforations from ft. to ft.	Sant 18 49 W.B.
perforations from ft. to ft.	Rock, med. black 49 55
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	Ruk med Skack 57 75
Manufacturer's Name	Basalr. Alask 75 83
Type Model No	Rack med black 83 125 W.B.
Diam Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is	
iowered below static level	- DEGELVEU
Was a pump test made? Yes W. No If yes, by whom?	o # 1000
d: gal./min. with ft. drawdown after hrs.	FEB 2 5 1980
"	WATER RESOURCES DEPT
AND TEST 95 " 88 " " "	SALEM, OREGON
Bailer test 60 gal./min. with 63 ft. drawdown after / hrs.	
esian flow g.p.m.	
Temperature of water Depth artesian flow encountered ft.	Work started 2-4 1980 Completed 2-5 1980
(9) CONSTRUCTION;	Date well drilling machine moved off of well 2-5 1980
Well seal—Material used Current	Drilling Machine Operator's Certification:
Well sealed from land surface to 54 ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal 10 to 20 in. Lives seal	best knowledge and belief.
Diameter of well bore below seal	[Signed] James Totelch Date 2-5, 1980
Number of sacks of cement used in well seal 12 sacks	Drilling Machine Operator's License No. 665
How was cement grout placed? Plessere ground unto	Drining Waterinie Operator's Electise No
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? ▼Yes □ No Plugs Size: location ft.	true to the best of my knowledge and belief. Name TROY GRIFFIM
Did any strata contain unusable water? 🕱 Yes 🗌 No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 900 HERMISTON AVE, HERMISTON OR
Method of sealing strata off	reignal Take Halling
Was well gravel packed? [] Yes [No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed from ft. to ft	Contractor's License No. 65 Date 2-5 1986