

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion

RECEIVED
MAY 14 1971
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
MAY 24 1971
STATE ENGINEER
SALEM, OREGON

State Well No. 4N/29-10 abd

State Permit No. UMAT 2826

(1) OWNER:

Name C. Beck
Address HERMISTON OREGON NE CORNER NW 1/4 SE 1/4 Section 10 T. 4N R. 29E W.M.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded

" Diam. from 0 ft. to 60 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 27 ft. below land surface Date 4/1/71
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____
Field: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Baller test 25 gal./min. with 8 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Umatilla Driller's well number
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 80 ft. Depth of completed well 80 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

| MATERIAL | From | To | SWL |
|--------------------------|-----------|-----------|------------|
| <u>SAND & GRAVEL</u> | <u>0</u> | <u>25</u> | |
| <u>CLAY</u> | <u>25</u> | <u>55</u> | |
| <u>SANDSTONE</u> | <u>55</u> | <u>80</u> | <u>2.7</u> |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Work started 3/27 19 71 Completed 4/1 19 71
Date well drilling machine moved off of well 5/13 19 71

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John Heubner (Date 5/5, 19 71)
(Drilling Machine Operator)

Drilling Machine Operator's License No. 357

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.R.I.C.E. DRILLING Co
(Person, firm or corporation) (Type or print)

Address 13525 NE CLACKAMAS ST

[Signed] G.P. Hall
(Water Well Contractor)

Contractor's License No. 405 Date 5/12, 19 71