WATER WELL REPORT STATE OF OREGON



RECEIVE Date Well No. 4/29E-18ad APR4 1983 PLEASE TYPE or PRINTER IRESOURCES DEPT.

	SALEM. OREGON	
(1) OWNER:	(10) LOCATION OF WELL:	
Name Johnnie Mayes	County Umatilla Driller's well number	
Address K7. 3, Box 3854	SE 14 NE 14 Section 18 T. 4 R. 29	W.M.
City Hermiston, State Or. 97838	The Table	division .
(2) TYPE OF WORK (check):	Address at well location: Highland Rd.	
New Well Deepening □ Reconditioning □ Abandon □	Hermiston, Or. 97838	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 50	
Part of the control o	Static level 43 ft. below land surface.	
Rotary Mud Dug Irrigation Test Well Other	Artesian pressure lbs. per square inc	
able Bored Thermal: Withdrawal Reinjection	(12) WELL LOG: Diameter of well below casing	
(5) CASING INSTALLED: Steel Plastic	Depth drilled /25 ft. Depth of completed well /25 ft	
Threaded Welded W	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry	
	1 for each change of formation, Report each change in position of C	at least one entry
"Diam. from	and indicate principal water-bearing strata.	waste Water Level
LINER INSTALLED:	MATERIAL From	To SWL
	Sandy soil 0	6
(6) PERFORATIONS: Perforated? Yes Vo		5
Type of perforator used	Grave/ 15	/8
Size of perforations in. by in.		68
perforations from ft. to ft.		0 water
perforations from		00
perforations from	Coarse gravel 100 1	24 water
(7) SCREENS: Well screen installed? Yes No	Light grey clay 124 1	25
Manufacturer's Name		
Type	Tr. I	
Diam. Slot Size Set from ft. to ft.		
Diam. Slot Size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? Fres The No If yes, by whom?		
Yield: gal./min. with ft. drawdown after bry		
# # # # # # # # # # # # # # # # # # #		
Air test 500 gal./min. with drill stem at 125 ft. 1 hrs.		
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow g.p.m.		
Temperature of water Depth artesian flow encounteredft.	Work started 3-1 19 83 Completed 3-2	
(9) CONSTRUCTION: Special standards: Yes \(\text{No } \text{No } \text{V}	Date well drilling machine moved off of well	198
Well seal—Material used Cement	(unbonded) Water Well Constructor Certification (if	1300
Well sealed from land surface to	This well was constructed under my direct conscricion	3.6-2 1 1
Diameter of well bore to bottom of seal	and information reported above are true to my best knowled	lge and belief
Diameter of well bore below sealin.	[Signed] Date	, 19
Number of sacks of cement used in well seal sacks How was cement grout placed? Fun ped with	Bonded Water Well Constructor Certification	
trimmy sina	Bond SB 36090 Issued by: Oregon Automobile Ins. (
pipex	(number) Surety Company Nan	ne
Was pump installed?	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and helief.	
Was a drive shoe used? Yes No Plugs Size: location ft	Name (Person, firm or corporation)	
Did any strata contain unusable water? Yes No	Address 1307 SW 23-1 Pendleton Or.	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
Type of Water? depth of strata	1) 4 1/2 1/11	
Method of sealing strata off	[Signed] Water Well Constructor	<i></i>
Was well gravel packed? ☐ Yes No Size of gravel:	Date3-5	19.83
Gravel placed from ft. to ft.		,