

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

NOV 27 1964 STATE OF OREGON (Please type or print)

UMAT 2972

State Well No. 4/29-32 L(1)

State Permit No. _____

(1) OWNER:

Name City of Stanfield
Address Stanfield Ore.

(2) LOCATION OF WELL:

County Umatilla Driller's well number
1/4 1/4 Section 32 T. 4 R. 29 W.M.
Bearing and distance from section or subdivision corner

TYPE OF WORK (check):

Drill Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 776 ft. to 714 ft. Gage 330
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal _____
Depth of seal " ft. Was a packer used? _____
Diameter of well bore to bottom of seal " in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No Top and bottom of
Was well gravel packed? Yes No Size of gravel: 1/2" liner
Gravel placed from " ft. to " ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 162 ft. below land surface Date 7-15-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Contractor

Yield: 660 gal./min. with 20 ft. drawdown after 5 hrs.
" 540 " " 12 " 5 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 55 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 778 ft. Depth of completed well 778 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Boulders hard gray	700	726
Sandy clay black	726	733
Rock gray medium	733	750
Boulders gray hard	750	759
Rock black soft	759	774
Rock black medium	774	778

Work started 6-22-64 19 Completed 7-14-64 19

Date well drilling machine moved off of well 7-15-64 19

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ben Dreyer Drilling Contractor
(Person, firm or corporation) (Type or print)

Address Rt. 1 Box 225 Hermiston, Oregon

Drilling Machine Operator's License No. 126

[Signed] Ben Dreyer
(Water Well Contractor)

Contractor's License No. 12 Date 7-15-64, 19