

RECEIVED

UMAT 301

1W/32E-15

STATE OF OREGON WATER WELL REPORT APR 17 1986

WATER RESOURCES DEPT PLEASE TYPE or PRINT IN INK

(for official use only)

(1) OWNER:

Name Pendleton Country Club Address Rt. 2, Box 94 City Pendleton State OR 97801

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [x] Driven [] Domestic [x] Industrial [] Municipal [] Rotary Mud [] Dug [] Irrigation [] Thermal: [] Withdrawal [] Reinjection [] Cable [] Bored [] Other: [] Piezometric [] Grounding [] Test []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Thermal: [] Irrigation [] Withdrawal [] Reinjection [] Other: [] Piezometric [] Grounding [] Test []

CASING INSTALLED:

Steel [x] Plastic [] Threaded [] Welded []

8" Diam. from +1 ft. to 31 ft. Gauge .250

LINER INSTALLED:

Steel [] Plastic [] Threaded [] Welded []

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? [] Yes [x] No

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No

Manufacturer's Name

Type Model No.

Diam. Slot Size Set from ft. to ft.

Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [x] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

Air test 60 gal./min. with drill stem at 200 ft. 1 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [] No [x]

Well seal—Material used Cement

Well sealed from land surface to 31 ft.

Diameter of well bore to bottom of seal 8 1/2 in.

Diameter of well bore below seal 14 in.

Amount of sealing material 14 sacks [x] pounds []

How was cement grout placed? Pressure grouted

Was pump installed? No Type HP Depth ft.

Was a drive shoe used? [] Yes [x] No Plugs Size: location ft.

Did any strata contain unusable water? [] Yes [x] No

Type of Water? depth of strata

Method of sealing strata off

Was well gravel packed? [] Yes [x] No Size of gravel: ft.

Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Umatilla 1/4 of Section 15 of Township 1N, Range 32E, WM.

Tax Lot Lot Block Subdivision

MAILING ADDRESS OF WELL (or nearest address)

Rt. 2, Box 94 Pendleton, OR 97801

(11) WATER LEVEL OF COMPLETED WELL:

Depth at which water was first found 14 ft.

Static level 4 ft. below land surface. Date 3-18-86

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Brown clay (0-14), Sandy gravel (14-20) WB, Gray Basalt (20-39), Red basalt with soapstone (39-53) WB, Gray basalt (53-97), Red basalt (97-106) WB, Gray basalt (106-200).

Date work started 3-10-86 /completed 3-18-86

Date well drilling machine moved off of well 3-18 1986

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date 19

(bonded) Water Well Constructor Certification:

Bond SB 36090 Issued by Oregon Automobile Ins. Co.

On behalf of Patrick C. Wallace, Wallace Drilling

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Patrick C Wallace (Water Well Constructor)

(Dated) 4-14-86

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690