

WATER WELL REPORT
STATE OF OREGON

REC-1
FEB 7 - 1985

UMAT
302

WATER RESOURCES DEPT
SALEM, OREGON

State Well No. 1W 32E-15 abn
State Permit No. _____

(1) OWNER:
Name JIM BROWN
Address ROUTE 2 PENDLETON OR
City _____ State _____

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Air Driven Rotary Mud Dug Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other Thermal: Withdrawal ReInjection

(5) CASING INSTALLED: Steel Plastic Threaded Welded
8" Diam. from +2 ft. to 150 ft. Gauge 250

LINER INSTALLED:
_____ " Diam. from _____ ft. to _____ ft. Gauge _____

(6) PERFORATIONS: Perforated? Yes No
Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Type _____ Model No. _____
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
_____ gal./min. with _____ ft. drawdown after _____ hrs.
Air test 150 gal./min. with drill stem at 325 ft. 1 hrs.
Bailer test 75 gal./min. with _____ ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water 56° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used PORTLAND CEMENT
Well sealed from land surface to 150 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 6 3/16 in.
Number of sacks of cement used in well seal 29 sacks
How was cement grout placed? TROMIE

Was pump installed? NO Type _____ HP _____ Depth _____ ft.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of Water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
County UMATILLA Driller's well number _____
NE 1/4 NE 1/4 Section 15 T. 1N R. 32E W.M.
Tax Lot # _____ Lot _____ Blk _____ Subdivision _____
Address at well location: _____

(11) WATER LEVEL: Completed well.
Depth at which water was first found 250 ft.
Static level 168 ft. below land surface. Date _____
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 6 3/16
Depth drilled 350 ft. Depth of completed well 350 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	3	
GRAVEL	3	125	
BROWN BASALT	125	190	
GRAY	190	200	
BROWN	200	240	
Red	240	250	
BROKEN BROWN	250	255	
GRAY	255	295	
BROWN	295	305	
BROWN RED	305	310	
BROWN	310	350	

Work started 1-16 1985 Completed 1-17 1985
Date well drilling machine moved off of well 1-18 1985

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Jay Burd Date 1-18 1985

Bonded Water Well Constructor Certification:
Bond _____ (number) Issued by: _____ Surety Company Name _____
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Jay Burd Well Drilling Inc (person, firm or corporation) _____ (Type or print)
Address 5543 SW Douglas Pendleton OR
[Signed] Jay Burd Water Well Constructor
Date 1-18 1985

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*45292-690