## WATER WELL REPORT STATE OF OREGON

## RECEIVED

FEB5 1981

WATER RESOURCES DEPT SALEM, OREGON

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name John Straughan	County Umatilla Driller's well number
Address OR+ 1 Box 563	18 14 18 14 Section 3 T. 171. R. 338. W.M.
City Pendleton State Of 97801	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
New Well □ Deepening ★ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft.
	Static level 300 ft. below land surface. Date /-22-81
Rotary Mud	Artesian pressure Ibs. per square inch. Date
Cable   Bored   Thermal: Withdrawal   Reinjection	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel   Plastic	Depth drilled $420$ ft. Depth of completed well $675$ ft.
Threaded  Welded	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry
Diam. from	for each change of formation. Report each change in position of Static Water Level
ft. Gauge	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
ft. Gauge	Basalf 255 315
(6) PERFORATIONS: Perforated? □ Yes □ No	Rock, black y green clayston 315 377
Type of perforator used	Rock, light brownspard 377 395
Size of perforations in. by in.	Basalr, hard gray 395 455
perforations from	Rick, black Green + ranclarplon +55 413 W.B.
perforations from	Rock, dark brown 473 511 W.B.
perforations from	Rock, med. black blue Clayton 511 557
	Dasaly 0 351 612
(7) SCREENS: Well screen installed?	Rock black 1 brown 612 660
Type	Rock, black   brown 660 675 WiB.
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
Drawdown is amount water level is lawared	
WELL TESTS:  below static level	
Was a pump test made? ☐ Yes 🕦 No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	- Company of the second of the
" " "	
test 500 gal./min. with drill stem at 675 ft. / hrs.	
Sealer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	<u> </u>
Temperature of water Depth artesian flow encountered ft.	Work started 1-19 1981 Completed 1-22 1981
(9) CONSTRUCTION: Special standards: Yes \( \text{No } \text{No } \text{Second } \)	Date well drilling machine moved off of well   19 8
Well seal—Material used Not disturbed	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are true to my best knowledge and belief.  [Signed]
Diameter of well bore below sealin.	(Drilling Machine Operator)
Number of sacks of cement used in well seal	Drilling Machine Operator's License No
How was cement grout placed?	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to
Was pump installed? Ma. Type HP Depth ft.	the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes ☐ No Plugs	Name TROY GRIFFIH  (Person, firm or corporation) (Type or print)
Did any strata contain unusable water?   Yes   No	Address 900 HERMISTON AVE, HERMISTON ORE
Type of Water? depth of strata	
Method of sealing strata off	[Signed] (Water Well Contractor)  Contractor's License No. (95 Date 1-22 19.8/
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	Contractor's License No. 65 Date 1-22,19.8!
Gravel placed from ft. to ft.	