

RECEIVED

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.700) WATER RESOURCES DEPT SALEM, OREGON

APR 8 1985

UMAT 3414

5N/28E-2522

(for official use only)

(1) OWNER:

Name Charles A. Bloodsworth Address Rt. 2, Box 2801 City Hermiston State Or 97838

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL:

Rotary Air [x] Driven [] Rotary Mud [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Thermal [] Irrigation [x] Withdrawal [] ReInjection [] Other: Piezometric [] Grounding [] Test []

(5) CASING INSTALLED:

Steel Threaded [x] Plastic Welded [] 12" Diam. from 2 ft. to 66 ft. Gauge 250

LINER INSTALLED:

Steel Threaded [] Plastic Welded []

(6) PERFORATIONS:

Perforated? [] Yes [x] No [] Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Air test 4000 gal./min. with drill stem at 70 ft. 1 hrs.

(9) CONSTRUCTION:

Special standards: Yes [] No [x] Well seal—Material used Cement Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 16 in. Diameter of well bore below seal 12 in. Amount of sealing material 14 sacks [x] pounds [] How was cement grout placed? Pressure grouted Was pump installed? No Type HP Depth ft. Was a drive shoe used? [x] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [x] No Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Umatilla SE 1/4 SE 1/4 of Section 25 Township 5N Range 28E WM. Tax Lot Lot Block Subdivision

MAILING ADDRESS OF WELL (or nearest address)

Rt. 2, Box 2801 Hermiston, Or. 97838

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 30 ft. Static level 30 ft. below land surface. Date 3-8-85 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12" Depth drilled 70 ft. Depth of completed well 70 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Entries: Sand (0-56 WB), Large gravel (56-70 WB)

Date work started 3-6-85 / completed 3-8-85 Date well drilling machine moved off of well 3-8 19 85

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date 19

(bonded) Water Well Constructor Certification:

Bond SB36090 Issued by Oregon Automobile Ins. Co. On behalf of Patrick C. Wallace Wallace Drilling

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Patrick C Wallace (Water Well Constructor)

(Dated) 3-30-85

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690