

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

UMATILLA
3417

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED
OCT 12 1976

State Well No. SN/28E-26C
State Permit No. 6-6974

(1) OWNER:
Name Lee Baggett
Address 1030 N. Fisher St. Hermiston, Oregon 97838

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED: Threaded Welded
" Diam. from 0 ft. to 7.7 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Boiler test 250 gal./min. with 125 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 77 ft.
Diameter of well bore to bottom of seal 11 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 9 sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
County Umatilla Driller's well number _____
N.E. 1/4 SW 1/4 Section 26 T. 57. R. 28E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
Depth at which water was first found 71 ft.
Static level 75 ft. below land surface. Date 10-1-76
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 280 ft. Depth of completed well 280 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Topsoil</u>	<u>0</u>	<u>2</u>	
<u>Sand</u>	<u>2</u>	<u>31</u>	
<u>Gravel & sand</u>	<u>31</u>	<u>49</u>	
<u>Claystone, blue & gravel</u>	<u>49</u>	<u>71</u>	
<u>Rock, med. black</u>	<u>71</u>	<u>77</u>	<u>W.B.</u>
<u>Basalt</u>	<u>77</u>	<u>194</u>	
<u>Basalt, hard, gray</u>	<u>194</u>	<u>211</u>	
<u>Rock, med. black</u>	<u>211</u>	<u>222</u>	
<u>Rock, light brown</u>	<u>222</u>	<u>235</u>	
<u>Rock, hard, light brown</u>	<u>235</u>	<u>253</u>	
<u>Rock, brown & blue claystone</u>	<u>253</u>	<u>280</u>	<u>W.B.</u>

Work started 9-30 1976 Completed 10-1 1976
Date well drilling machine moved off of well 10-1 1976

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] James T. Leitch Date 10-1, 1976
(Drilling Machine Operator)
Drilling Machine Operator's License No. 665

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name TRAY GRIFFIN
(Person, firm or corporation) (Type or print)
Address 900 HERMISTON AVE. HERMISTON ORE.
[Signed] Tray Griffin
(Water Well Contractor)
Contractor's License No. 65 Date 10-1, 1976