

RECEIVED

APR 11 1967

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

UMAT 3446

WATER WELL REPORT STATE ENGINEER

STATE OF OREGON (Please type or print)

State Well No. 5N/28-27E

G-4260

State Permit No.

(1) OWNER:

Name Charles Kik
Address St 2 Box 29
Hermiston Oregon 97838

(2) LOCATION OF WELL:

County Umatilla Driller's well number
1/4 Section 27 T. 5 N R. 28 E. W. M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]
8" Diam. from 0 ft. to 64 ft. Gage 250
6" Diam. from 189 ft. to 229 ft. Gage 250

(7) PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Ruddled Clay
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 50 ft. below land surface Date 3-18-67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 40 gal./min. with 30 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 279 ft. Depth of completed well 279 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Topsoil, Sand, Yellow clay, Blue clay, Gray sand & rock med., Black rock - Hard basalt, Gray rock - hard, Blue clay or shale, Black rock, Hard black rock, Med hard black rock/w clay.

To drill deeper than well will have to be cased at 279 ft

Work started 1-31 1967 Completed 3-18 1967
Date well drilling machine moved off of well 3-22 1967

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME TROY GRIFFIN (Type or print)

Address 925 HERMISTON AVE, HERMISTON ORE

Drilling Machine Operator's License No. 15

[Signed] Troy Griffin (Water Well Contractor)

Contractor's License No. 65 Date 3-30 1967