

WATER WELL REPORT
STATE OF OREGON

UMAT
3529

UMAT 3529

RECEIVED

DEC 13 1982

State Well No.

5W/28E-34d

PLEASE TYPE OR PRINT IN INK
WATER RESOURCES DEPT.
SALEM, OREGON

State Permit No.

(1) OWNER:

Name TROY GRIFFIN
Address 900 HERMISTON AVE
City HERMISTON State OR. 97838

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☒ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:

Steel ☒ Plastic ☐
Threaded ☐ Welded ☒

6" Diam. from 1 ft. to 132 ft. Gauge 2.50
" Diam. from _____ ft. to _____ ft. Gauge _____

LINER INSTALLED:

" Diam. from _____ ft. to _____ ft. Gauge _____

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used _____

Size of perforations _____ in. by _____ in.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____

Type _____ Model No. _____

Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Field: _____ gal./min. with _____ ft. drawdown after _____ hrs.

AIR TEST 150 " drill stem at 175' 1 "

Air test 50 gal./min. with drill stem at 125 ft. 1 hrs.

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m.

Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☒

Well seal—Material used Cement

Well sealed from land surface to 132 ft.

Diameter of well bore to bottom of seal 10" to 20" Lower seal 8"

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 12 sacks

How was cement grout placed? Pressure Grouted

Was pump installed? No Type _____ HP _____ Depth _____ ft.

Was a drive shoe used? ☒ Yes ☐ No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of Water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number _____
SE 1/4 SE 1/4 Section 34 T. 57N. R. 28E. W.M.

Tax Lot # _____ Lot _____ Blk _____ Subdivision _____

Address at well location: _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 115 ft.

Static level 92 ft. below land surface. Date 11-17-82

Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	1	
Boulders	1	15	
Sand, gray	15	92	
Sand, blue & gravel	92	124	W.B.
Sand, blue	124	127	
Rock, black w/ green Claystone	127	150	
Rock, black w/ blue Claystone	150	175	
Basalt	175	187	
Rock, med., black	187	192	W.B.
Basalt	192	200	

Work started 11-15 1982 Completed 11-17 1982

Date well drilling machine moved off of well 11-17 1982

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] James T. Smith Date 11-17, 1982

Bonded Water Well Constructor Certification:

Bond 1648428 Issued by: TRAVELERS
(number) Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name TROY GRIFFIN (Type or print)

Address 900 HERMISTON AVE, HERMISTON OR.

[Signed] Troy Griffin

Water Well Constructor

Date 11-17, 1982

NOTICE TO WATER WELL CONSTRUCTOR

The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP-45292-690

UMAT 3529

COMPLETED

For Official Use Only:

Received Date: _____

County Well Log ID #

Well Identification Tag #

umat 3529

31043

WELL IDENTIFICATION APPLICATION RECEIVED**BUYER/CURRENT WELL OWNER:**

FEB 05 1999

Name: _____

RONALD J WHITE

WATER RESOURCES DEPT.
SALEM, OREGON

Mailing Address: _____

PO Box 389

City: _____

HERMISTON

State: _____

OR

Zip: _____

97838

Phone: _____

days

541-567-7534

WELL LOCATION:

County: _____

UMATILLA

Owner's Well Number: _____

5N/28E-34dd

Township: _____

5

Nor S,

Range: _____

28

Eor W,

Section: _____

34 T. SE 1/4 SE 1/4

Tax Lot Number: _____

1904

Type of Well: water supply _____

X

monitoring _____

Street Address of Well (if different from above): _____

80397 Hwy 39.5 N Hermiston OR

97838

WELL INFORMATION: (do not complete remainder of application if well log is available)

Start Card Number: _____

Approx. Construction Date: _____

Well Constructor: _____

Name of Owner at Time of Construction: _____

Well Depth (in feet): _____

200

Static Water Level (in feet): _____

92.0

Diameter of Exposed Well Casing (in inches): _____

Does this well have a formal water right associated with it? Yes: _____

No: _____

If Yes: Application #: _____

Permit #: _____

Certificate #: _____

Please Return Completed Form to:

Larry D. McQueen
Well Identification Program
Oregon Water Resources Department
158 12th Street NE
Salem, OR 97310