NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
. are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion. WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

UMAT 3551 State Well No. 5 N / 28 E - 34

State Permit No.

(1) OWNER: ρ	(10) LOCATION OF WELL:
Name Keth Smith	County Umatilla Driller's well number
Address P.O. By 745	14 14 Section 34 T. 571. R. 288. W.M.
Hermister Oregon 97838	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	Tay dot 9100
New Well 🛱 Deepening 🗆 Reconditioning 🗅 Abandon 🗅	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 95 ft.
Rotary ☑ Driven ☐ Domestic ☑ Industrial ☐ Municipal ☐	Static level /00' ft. below land surface. Date 7-3/-19
Dug	Artesian pressure lbs. per square inch. Date
5) CASING INSTALLED: Threaded Welded 4 "Diam. from 14 ft. to 145 ft. Gage	(12) WELL LOG: Diameter of well below casing 6. Depth drilled 209 ft. Depth of completed well 209 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
(6) PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	Sand 0 72
perforations fromft.	Gaystone green 72 95
perforations from ft. to ft.	Clariton aces 108 136
perforations fromft. toft.	Baself flack Varein Claustine 136 142
(7) SCREENS: Well screen installed? Yes No	Basalt black 142 188
Manufacturer's Name	Banalt, Abrous, black 188 201 W.B.
Type Model No.	Basall Hack 201 209
Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.	<u>.</u>
Set Holl II. 10 II.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? [] Yes M No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
(II	/\ue_10 (979)
AIR TEST 75 " 90 " 1"	WATER LIESOURCES DEPT
Baller test 45 gal./min. with 64 ft. drawdown after / hrs.	SALEM, OREGON
Artesian flow g.p.m.	
Femperature of water Depth artesian flow encountered ft.	Work started 7-27 1979 Completed 7-3/ 1979
(9) CONSTRUCTION;	Date well drilling machine moved off of well 7:3/ 1979
Well seal-Material used Clement	Drilling Machine Operator's Certification:
Well sealed from land surface to 145 ft.	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal 10 to 20 in. Lines seek	Materials used and information reported above are true to my best knowledge and pelicif.
Diameter of well bore below seal in.	[Signed] War July Date 7-3/ 1979
Number of sacks of cement used in well seal 12 sacks	(Drilling Machine Operator)
How was cement grout placed? Theasund granlet into	Drilling Machine Operator's License No
n n n n n n n n n n n n n n n n n n n	Water Well Contractor's Certification:
是一个人,我们就是一个人,我们就是一个人,我们就是一个人,我们就是一个人,我们就是一个人,我们就是一个人,我们就是一个人,我们就是一个人,我们就是一个人,我们就	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? 📈 Yes 🗌 No Plugs Size: location ft.	Name TROY GRIFFIN
Did any strata contain unusable water? 🔲 Yes 💆 No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 900 HERMISTON AVE, HERMISTON OFE
Method of sealing strata off	[Signed] Moy Shiffen.
Was well gravel packed? [] Yes X No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 65 Date 7-31, 1979