

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED WATER WELL REPORT **RECEIVED**
APR 9 1973 STATE OF OREGON JAN 29 1973
STATE ENGINEER SALEM, OREGON STATE ENGINEER STATE ENGINEER
SALEM, OREGON SALEM OREGON

5N/28E-34

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

Please file or print
Do not write above this line
State Well No. 5N/28E-34
Permit No.

UMAT
3584

(1) OWNER:

Name Oscar V. Johnson
Address Rt 2 Box 120B
Hermiston Oregon 97838

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 11.0 ft. Gage 2.50
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Baker test 45 gal./min. with 30 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? Sandy depth of strata 90
Method of sealing strata off Casing
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number
1/4 Section 34 T. 57. R. 28 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 90 ft.
Static level 70 ft. below land surface. Date 1-24-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 115 ft. Depth of completed well 115 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Sand, Gray	2	85	
Sand + Gravel	85	102	
Gravel	102	115	W.B.

Work started 1-22 1973 Completed 1-24 1973
Date well drilling machine moved off of well 1-24 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Gregory H. Griffin Date 1-24, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 15

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name TROY GRIFFIN
(Person, firm or corporation) (Type or print)
Address 900 HERMISTON AVE., HERMISTON ORE.
[Signed] Troy Griffin
Water Well Contractor)
Contractor's License No. 65 Date 1-24, 1973