ORIGINAL WATER WE	ELL REPORTING 5/	V/28-34H	
Duplicate with the STATE ENGINEER.  STATE ENGINEER.  STATE OF OREGON UMA			
SALEM, OREGON SIAL ENGINEER	State Permit No.	1014	
(1) OWNER: SALEM. OREGON	(11) WELL TESTS: Drawdown is amount lowered below static le	water level is evel	
Address	Was a pump test made? ☐ Yes ☐ No If yes, by whom?		
HERMISTON OREGON	Yield: gal./min. with ft. drawdown after hrs.		
	" " " "		
(2) LOCATION OF WELL:  County Owner's number, if any—	Bailer test 50 gal./min. with 10 ft. drawdown after hrs.		
SE, 4NE 4 Section 34 T. 5 // R. 28 E. W.M.	Artesian flow g.p.m. Date		
Bearing and distance from section or subdivision corner	Temperature of water Was a chemical analysis made?   Yes No		
1620S. and left of W From	(12) WELL LOG: Diameter of well inches.		
the N. E. Corner of Seption 34	Depth drilled 159 ft. Depth of completed well 159 ft.		
francisco de la companya della companya della companya de la companya de la companya della compa	Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each		
	structum penetratea, with at least one entry for each c	hange of formation.	
MADE OF MODE (1 1)	MATERIAL	FROM TO	
TYPE OF WORK (check):  ew Well Deepening   Reconditioning   Abandon   Abandon	GRAVEL + SAND	0 60	
If abandonment, describe material and procedure in Item 11.	BLUE- GREEN SHALE	105 130	
(4) PRODUCED LIGHT ( L. L.)	BLACK ROCK	130 15%	
(4) PROPOSED USE (check): (5) TYPE OF WELL:	BROWH ROCK + WATER	156 159	
tration Test Well Cother Cable Jetted	HIT CRAKEL AT	169	
rigation A Test Well   Other     Dug   Bored			
(6) CASING INSTALLED: Threaded   Welded			
8 " Diam. from			
" Diam. fromft. toft. Gage"  Diam. fromft. toft. Gage			
(7) PERFORATIONS: Perforated?  Yes No			
Type of perforator used  SIZE of perforations in. by in.		\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	
perforations fromft. toft.		\	
perforations from ft. to ft.		X	
perforations fromft. toft.			
perforations fromft. toft.			
SCREENS: Well screen installed			
facturer's Name			
Diam. Slot size Set from ft. to ft.	•		
Diam Slot size Set from ft. to ft.	Work started 5-15 1959 Completed 5	-21 1959	
CONSTRUCTION:	(13) PUMP:		
well gravel packed? [] Yes No Size of gravel:	Manufacturer's Name		
Gravel placed fromft. toft.	Type: Line Shaft The Stine HP. 10		
Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.  Material used in seal—			
Did any strata contain unusable water?   Yes No	Well Driller's Statement:		
Type of water? Depth of strata	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Method of sealing strata off	NAME TROY GRIFFIH		
(10) WATER LEVELS:	(Person, firm, or corporation) (Type or print)		
Static level \$6 ft. below land surface Date	Address HERMISTON OREGON		
Artesian pressure lbs. per square inch Date	lbs, per square inch Date Driller's well number		
Log Accepted by: I for a [Signed] I ray I suffin.			
[Signed] Leny of Date 6 7 197			
(Owner)	License No. 65 Date 6	5 , <sub>19</sub> 5 9	
·			