STATE OF OREGON

WATER WELL REPORT

(as required by ORS 537.765)

RECEIVED
FEB 13 1986
WATER RESOURCES DEPT
SALEM, OREGON

PLEASE TYPE or PRINT IN INK

UMAT 3605

5N/28E-35c

(for official use only)

(1) OWNER:

Name Leroy Haagen

Address 8326 Middleway

City Vancouver State WA 98664

(2) TYPE OF WORK (check):

New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☑ Driven ☐

Rotary Mud ☐ Dug ☐

[illegible] ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☑ Industrial ☐ Municipal ☐

Irrigation ☐ Thermal: Withdrawal ☐ Reinjection ☐

Other: Piezometric ☐ Grounding ☐ Test ☐

(5) CASING INSTALLED:

Steel ☑ Plastic ☐

Threaded ☐ Welded ☑

10" Diam. from +1 ft. to 140 ft. Gauge .250

[illegible]" Diam. from ft. to ft. Gauge

LINER INSTALLED: Steel ☐ Plastic ☐ Threaded ☐ Welded ☐

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? ☐ Yes ☑ No

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☑ No

Manufacturer's Name

Type Model No.

Diam. Slot Size Set from ft. to ft.

Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

[illegible] a pump test made? ☐ Yes ☑ No If yes, by whom?

[illegible]d: gal./min. with ft. drawdown after hrs.

" " " "

Air test 200 gal./min. with drill stem at 140 ft. 1 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

[illegible]sian flow g.p.m.

[illegible]mperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☑

Well seal—Material used Bentonite

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 14 in.

Diameter of well bore below seal 10 in.

Amount of sealing material 8 sacks ☑ pounds ☐

How was cement grout placed? Poured between 10" and 14" pipe

Was pump installed? No Type HP Depth ft.

Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☑ No

Type of Water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☑ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Umatilla ¼ SW ¼ of Section 35 of

Township 5N (Township is North or South), Range 28E (Range is East or West), WM.

Tax Lot Lot Block Subdivision

MAILING ADDRESS OF WELL (or nearest address)

Near corner of Joy Lane & Alpine Dr.
Hermiston, OR 97838

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 110 ft.

Static level 110 ft. below land surface. Date 1-16-86

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sand	1	118	
Med. gravel	118	136	WB
Large gravel	136	140	WB

Date work started 1-15-86 /completed 1-16-86

Date well drilling machine moved off of well 1-16 1986

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date , 19

(bonded) Water Well Constructor Certification:

Bond SB36090 (number) Issued by: Oregon Automobile Ins. Co. (Surety Company Name)

On behalf of Patrick C. Wallace Wallace Drilling (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Patrick C. Wallace (Water Well Constructor)

(Dated) 1-27-86

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690