

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. ....

State Permit No. ....

STATE ENGINEER, SALEM, OREGON 97301  
within 30 days from the date  
of well completion.

**UMAT**  
3615

**RECEIVED**  
JAN 26 1976  
WATER RESOURCES DEPT.

5X-282-35

**(1) OWNER:**

Name Haagen Landover Hills  
Address 8312 Mill Plain Blvd.  
Vancouver Wash. 98664

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
6" Diam. from 0 ft. to 133 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " "  
" " " "  
air 75 gal./min. with 95 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement & bentonite  
Well sealed from land surface to 133 ft.  
Diameter of well bore to bottom of seal 9 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 4 sacks  
Number of sacks of bentonite used in well seal 1 sacks  
Brand name of bentonite National  
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**

County Umatilla Driller's well number  
N.W 1/4 NW 1/4 Section 35 T. 5N R. 28E. W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 108 ft.  
Static level 75 ft. below land surface. Date 1-22-76  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing 6"  
Depth drilled 279 ft. Depth of completed well 279 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Sand	2	85	
Sand & gravel	85	108	
Claystone, green	108	118	
Claystone, blue	118	125	
Rock, med. black	125	133	
Basalt	133	262	
Rock, hard, gray	262	272	
Rock, brown	272	276	W.O.
Rock, black	276	279	

Work started 1-19 1976 Completed 1-22 1976  
Date well drilling machine moved off of well 1-22 1976

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Troy Griffin Date 1-22, 1976  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 15

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name TROY GRIFFIN  
(Person, firm or corporation) (Type or print)

Address 900 HERMISTON AVE, HERMISTON ORE

[Signed] Troy Griffin  
(Water Well Contractor)

Contractor's License No. 65 Date 1-22, 1976