STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

RECEIVED
MAR 13 1985
WATER RESOURCES DEPT
SALEM, OREGON

UMAT 3726

5N/29E-29bC
(for official use only)

PLEASE TYPE or PRINT IN INK

(1) OWNER:
Name Allen Whitehall
Address Rt. 3, Box 3856
City Hermiston State Or 97838

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☑ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Thermal: Withdrawal ☐ Reinjection ☐
Other: Piezometric ☐ Grounding ☐ Test ☐

(5) CASING INSTALLED: Steel ☑ Threaded ☐ Plastic ☐ Welded ☑
6" Diam. from +1 ft. to 52 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED: Steel ☐ Threaded ☐ Plastic ☐ Welded ☐
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
Air test 40 gal./min. with drill stem at 52 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes ☐ No ☑
Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Amount of sealing material 12 sacks ☑ pounds ☐
How was cement grout placed? Pressure grouted
Was pump installed? No Type HP Depth ft.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:
County Umatilla SW ¼ NW ¼ of Section 29 of
Township 5N (Township is North or South), Range 29E (Range is East or West), WM.
Tax Lot Lot Block Subdivision
MAILING ADDRESS OF WELL (or nearest address)
Rt. 3, Box 3856
Hermiston, Or. 97838

(11) WATER LEVEL of COMPLETED WELL:
Depth at which water was first found 34 ft.
Static level 30 ft. below land surface. Date 2-9-85
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 52 ft. Depth of completed well 52 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy soil	0	8	
Fine gravel	8	22	
Sand	22	45	WB
Coarse gravel	45	52	WB

Date work started 2-8-85 /completed 2-9-85
Date well drilling machine moved off of well 2-9 1985

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date , 19

(bonded) Water Well Constructor Certification:
Bond SB 36090 (number) Issued by: Oregon Automobile Ins. Co. (Surety Company Name)
On behalf of Patrick C. Wallace, Wallace Drilling (type or print name of Water Well Constructor)
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
(Signed) Patrick Wallace (Water Well Constructor)
(Dated) 2-28-85

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690