## WATER WELL REPORT

STATE OF OREGON





## RECEIVED

JUN 12 1981 State Well No.

WATER RESOURCES DEPTermit No. SALEM, OREGON

(1) OWNED:	(10) 7.004 57-07-07
(1) OWNER:	(10) LOCATION OF WELL:
Name Phil Bea Champ	County UM atilla Driller's well number
Address 18+2 1364 2836 City Hermitor State Of 97K38	N.W 4 SW 4 Section 31 T. 571, R. 29 E. W.M.
	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
New Well	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 63 ft.
	Static level 32 ft. below land surface. Date 5-28-81
Rotary Mud  Dug  Irrigation Test Well  Other	Artesian pressure lbs. per square inch. Date
☐ Bored ☐ Thermal: Withdrawal ☐ Reinjection ☐	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel	Depth drilled 97 ft. Depth of completed well 97 ft.
Threaded  Welded Welded Dimension	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry
	for each change of formation. Report each change in position of Static Water Level
"Diam. from	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
	Topsvel 0 2
(6) PERFORATIONS: Perforated? □ Yes SNo	Jan, gray 2 72
Type of perforator used	Jand, blice 72 86 W.B.
Size of perforations in. by in.	Thavel 86 97 W.B.
perforations from ft. to ft.	
perforations from ft. to ft.	
perforations from	
(7) SCREENS: Well screen installed?   Yes No	
Manufacturer's Name	
Type Model No.	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
a pump test made?   Yes No If yes, by whom?	
rield: gal/min. with ft. drawdown after hrs.	
" " " "	
Air test 300 gal/min. with drill stem at 75 ft. / hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
in flow g.p.m.	
Depth artesian flow encountered ft.	Work started 5-27 1981 Completed 5-28 1981
9) CONSTRUCTION: Special standards: Yes \( \text{No M} \)	Date well drilling machine moved off of well 5-28 19 8/
Well seal—Material used	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are true to my jest knowledge and helief.
Diameter of well bore below sealin.	[Signed] Andlet T. S. Lee Date 5-78, 19.8
Number of sacks of cement used in well seal	Drilling Machine Operator's License No
low was cement grout placed? Trime pupe from bottom to	
top of brusique drill hole	Water Well Contractor's Certification:
Vas pump installed?	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Vas a drive shoe used? 12 vs.  No  \text{Plugs}  \text{Size: location}  \text{ft}.	Name TROY GRIFFIN
Did any strata contain unusable water?  Yes No	(Type or print)  Address 900 HERMISTON AVE HERMISTON OF
ype of Water? depth of strata	Address 100 11-10 Miles 11 MVL 17 E PHILD 1817 UN
Method of sealing strata off	[Signed] Man Wall Colored
Vas well gravel packed? ☐ Yes Ŋ No Size of gravel:	(Water Well Confractor)  Contractor's License No
Fravel placed from ft. to ft.	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2