

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97301
within 30 days from the date
of well completion.

UMAT
3865

STATE OF OREGON
(Please type or print)

State Well No. 5N/32E-26
State Permit No. _____

(Do not write above this line)

G 0374
57336

(1) OWNER:

Name Fred Hice
Address 208 N.E. Furrish
Pendleton, Oregon 97801

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
4 " Diam. from 0 ft. to 24 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
1 1/2 hr
Baker test 150 gal./min. with 70 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 24 ft.
Diameter of well bore to bottom of seal 11 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 3 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons _____
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number _____
1/4 1/4 Section 26 T. 54 R. 32E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 60 ft.
Static level 25 ft. below land surface. Date 12-3-73
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 120 ft. Depth of completed well 120 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Topsoil</u>	<u>0</u>	<u>8</u>	
<u>Clay, yellow + gravel</u>	<u>8</u>	<u>16</u>	
<u>Rock, med. brown</u>	<u>16</u>	<u>45</u>	
<u>Basalt</u>	<u>45</u>	<u>57</u>	
<u>Rock, light brown</u>	<u>57</u>	<u>85</u>	<u>W.B.</u>
<u>Basalt</u>	<u>85</u>	<u>91</u>	
<u>Rock, light brown</u>	<u>91</u>	<u>115</u>	<u>W.B.</u>
<u>Basalt</u>	<u>115</u>	<u>120</u>	

Work started 11-30 1973 Completed 12-3 1973
Date well drilling machine moved off of well 12-3 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] James Leubke Date 12-3, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 665

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name TROY GRIFFIN
(Person, firm or corporation) (Type or print)
Address 900 HERMISTON AVE, HERMISTON, ORE
[Signed] Troy Griffin
(Water Well Contractor)
Contractor's License No. 65 Date 12/3, 1973