

(1) OWNER: SALEM, OREGON
Name Raymond C. Cox
Address 207 1/2 Bldg 3
Milton Free Water Co.

(2) LOCATION OF WELL:
County Yamhill Owner's number, if any—
SW 1/4 NE 1/4 Section 7 T. 5N R. 36E W.M.
Bearing and distance from section or subdivision corner

TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
6" Diam. from 0 ft. to 1.8 ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 10 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] (Owner) Date, 19

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? -
Yield: 47.2 gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Bailer test 9.2 gal./min. with 15 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 6 inches.
Depth drilled 85 ft. Depth of completed well 95 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Thin, 6 ft. Sand Rock & gravel	0	6
Abandon log	6	22
Gray Bonall Rock	18	26
Orange-brown Brown Rock	26	30
Gray Bonall Rock	30	40
get very hard Gray for 6 ft. then softer		53
Hard Gray Bonall	53	61
Very hard Gray - Bonall	61	62
Hard a little like they -	62	66
For Two Days Run		
Very hard Gray - Rock too	61	78
Dis. Very hard Rock	78	95-15
More water in Gray Bonall Rock		
85 - ft drilled hole		
There was 10 - ft. of dug hole -		

Work started 19 5.1 Completed 19 5.1

(13) PUMP:
Manufacturer's Name Jacuzzi
Type: Centrifugal HP. 1

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R. W. Davis (Person, firm, or corporation) (Type or print)
Address Milton Free Water
Driller's well number
[Signed] R. W. Davis (Well Driller)
License No. 157 Date Sep 12, 1958