

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

UMAT
 4095

WATER WELL REPORT

RECEIVED
 AUG 27 1964

STATE OF OREGON STATE ENGINEER
 (Please type or print)

State Well No. 6N/34-15L
 State Permit No. G-1775

(1) OWNER:

Name U. H. Berney Estate
 Address Walter Berney (Executor)
825 Whitman St, Walla Walla, Washington

(2) LOCATION OF WELL:

County Umatilla Driller's well number 373
NE 1/4 SW 1/4 Section 15 T. 6 N R. 34 E. W.M.
 Bearing and distance from section or subdivision corner
Well Location 496' South & 1246' West of
Center of said section 15 Twp 6N. R. 34 E.W.M.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
12" Diam. from surface ft. to 122' 7" ft. Gage 277
 " Diam. from " ft. to " ft. Gage
 " Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used
 Size of perforations in. by in.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____ Model No. _____
 Type _____
 Diam. Slot size Set from " ft. to " ft.
 Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Gravel & Clay
 Depth of seal 37' ft. Was a packer used? no
 Diameter of well bore to bottom of seal 16 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 23 ft. below land surface Date 3/27/61
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 600 gal./min. with 67 ft. drawdown after 10 hrs.
 " 500 " 52 " " "
 " " " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 12"
 Depth drilled 226 ft. Depth of completed well 226 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
soil	0	5
hardpan	5	18
sand & clay	18	37
gravel & sand	37	119
hard cemented gravel with		
water bearing stratas	119	225
brown clay & sand	225	226

Work started 2/20 1961. Completed 3/27 1961
 Date well drilling machine moved off of well 3/28 1961

(13) PUMP:

Worthington (8 stages of 10" bowl s)
 Manufacturer's Name 150' of 6" X 1 1/4" column & shaft
 Type: Turbine (electric) H.P. 50HP 440 V

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. E. Ruther & Son
 (Person, firm or corporation) (Type or print)

Address Route # 4, Walla Walla, Washington

Drilling Machine Operator's License No. #138

[Signed] William E Ruther
 (Water Well Contractor)

Contractor's License No. 373 Date 8/26, 1964