NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON MAY 5 1975

(Please type or print) STATE ENGINEER

(Do not write above this line SALEM, OREGONState Permit No.

(1) OWNER:	(10) LOCATION OF WELL:	(4100)
Name Sherman Thomas DBA/ Lowden Ranch	County Umatilla Driller's well no	umber
Address Lowden, Washington 99342	SE 14 SW 14 Section 17 T. 6	R. 34 E. W.M.
	Bearing and distance from section or subdivisi	ion corner
(2) TYPE OF WORK (check):	200 ft. N of S line & 250'	W of center line
New Well ☐ Deepening ☑ Reconditioning ☑ Abandon ☐	of sec. 17.	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	المر
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found unknown ft.	
Rotary Driven Domestic Industrial Municipal Domestic Industrial Municipal	Static level 27 ft. below land	surface Date 1-19-75
Cable 4 Jetted 1 -		guillace. Date
Dug	Artesian pressure Ibs. per squar	re inch. Date
CASING INSTALLED: Threaded Welded 5 .250 8 "Diam. from + 15 ft. to 303 5 ft. Gage .250	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,	
"Diam. from ft. to ft. Gage		
ft. Gage		
PERFORATIONS: Perforated? To Yes I No.	with at least one entry for each change of forma position of Static Water Level and indicate prin	
Willing Wachine		T 1. T
Type of periorator used	Old Well	From To SWL 0 290
Size of perforations 4 in. by 4 in. 12 pwr/ft. 113 292	Gnarrol	290 294
12 per/ft. perforations from 113 ft. to 292 ft.	Clay with gravel	294 309
perforations from ft. to ft.	79 - 79	309 344
perforations from ft. to ft.	Clay yellow :	344 352
(7) SCREENS: Well screen installed? Yes No	Blue Clay	352 355
Manufacturer's Name		
TypeModel No.		
Diam. Slot size from ft. to ft.		
Diam Slot size Set from ft. to ft.	The second of th	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	* 1 Table 1	
Was a pump test made? ☑ Yes ☐ No If yes, by whom? driller	The second secon	
Yield: 1,000 gal./min. with ft. drawdown after 10 hrs.	- 4	
sted with 300 "ft., 250 ft., 200 ft. and "	1 2 4	
150 ft. of column. No room for measuring device		
Bailer test gal./min. with ft. drawdown after hrs.	man to the second secon	
A tesian flow g.p.m.	4 A A A A A A A A A A A A A A A A A A A	
50 _ 1 _ 1 _ 1 _ 1 _ 1 _ 1 _ 1 _ 1 _ 1 _	Work started 2 Dec 1974 Complet	ed 16 apr 1975
	Work started 2 Dec 1974 Complet Date well drilling machine moved off of well	23 Jan 1975
(9) CONSTRUCTION:		
Well seal-Material used old well - unknown	Drilling Machine Operator's Certification:	
Well sealed from land surface to ft.	This well was constructed under my Materials used and information reported	above are true to my
Diameter of well bore to bottom of seal in.	best knowledge and belief.	# A i mm
Diameter of well bore below sealin.	[Signed] William & Martine (Drilling Machine Operator)	Date 36 Apr, 19 75
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No.	137
Number of sacks of bentonite used in well seal sacks	Driving Machine Operator & License 110.	
Brand name of bentonite	Water Well Contractor's Certification:	i i i i i i i i i i i i i i i i i i i
Number of pounds of bentonite per 100 gallons of waterlbs./100 gals.	This well was drilled under my jurisdiction and this report is	
Was a drive shoe used? Yes □ No Plugs Size: location ft.	true to the best of my knowledge and belief.	
Did any strata contain unusable water? Yes 4 No	Name Thomas R. Ruther (Type or print)	
	1421 Circle Dr. Walls	
Type of water? depth of strata	Address	
Method of sealing strata off	[Signed] Monroa M. Malkle	
Was well gravel packed? ☐ Yes 爲 No Size of gravel:	(Water Well Cont	70 Amm 75
Gravel placed from ft. to ft.	Contractor's License No. 374 Date	30 Apr. , 19 75