6N/34-26 aa

UMAT 4120

RECEIVED MAR 26 1965 STATE ENGINEER SALEM, OREGON

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT 65957
STATE OF OREGON 83059

State Well No. 6N/34-~~23~~aa66

State Permit No. .....

(1) OWNER:
Name Earnest Muller

Address Helix, Oregon

(2) LOCATION OF WELL:
County Umatilla Owner's number, if any—

¼ ¼ Section 23 T. 6N R. 34E W.M.

Bearing and distance from section or subdivision corner

1085 ft. West from S.E. Corner of Sec. 23

(3) TYPE OF WORK (check):
New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐

Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐

Cable ☒ Jetted ☐

Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☐

12 " Diam. from 0 ft. to 50 ft. Gage .....

..... " Diam. from ..... ft. to ..... ft. Gage .....

..... " Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No

Type of perforator used

SIZE of perforations 6 in. by 1/4 in.

4 perforations from every 2 ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

(8) SCREENS:
Well screen installed ☐ Yes ☐ No

Manufacturer's Name .....

Type ..... Model No. .....

..... Slot size ..... Set from ..... ft. to ..... ft.

Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:
Was well gravel packed? ☒ Yes ☐ No Size of gravel: .....

Gravel placed from ..... ft. to ..... ft.

Was a surface seal provided? ☐ Yes ☐ No To what depth? ..... ft.

Material used in seal—

Did any strata contain unusable water? ☐ Yes ☐ No

Type of water? Depth of strata

Method of sealing strata off

(10) WATER LEVELS:
Static level 6 ft. below land surface Date 2-26-65

Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Ernest Muller Date March 19 65
(Owner)

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? -

Yield: 200 gal./min. with 19 ft. drawdown after 5 hrs.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:
Diameter of well 12 inches.

Depth drilled 90 ft. Depth of completed well 90 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Dug Hole	16	16
Clay	6	22
Gravel & silt	18	40
Cement gravel	30	90

Work started 2-15 1965 Completed 2-27 1965

(13) PUMP:
Manufacturer's Name .....

Type: ..... H.P. .....

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Moore & Anderson
(Person, firm, or corporation) (Type or print)

Address P.O. Box 1228, Walla Walla, Wash.

Driller's well number .....

[Signed] T. Henderson
(Well Driller)

License No. 205 Date 3-1, 1965

(USE ADDITIONAL SHEETS IF NECESSARY)