

RECEIVED
MAR 26 1959

G-1401

WATER WELL REPORT
STATE ENGINEER OF OREGON
SALEM, OREGON

UMAT
4131

State Well No. 6N/24-24Q
State Permit No.

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

(1) OWNER:
Name Mrs. Frances Fitzsimmons
Address Weston Oregon

(2) LOCATION OF WELL:
County Umatilla Owner's number, if any—
SW 1/4 SE 1/4 Section 24 T. 6N R. 34 B.W.M.
Bearing and distance from section or subdivision corner
1320 feet (?)

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded X
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used *Man*
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name
Type Model No.
Inch. Slot size Set from ft. to ft.
Inch. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? *Soft* Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level *8* ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] *Lawrence Fitzsimmons* Date *Mar. 22*, 19-*59*
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Well was 40 sprinkler - 24 hrs. per day all summer - water not running out of lines -
Bailer test *120* gal./min. with *4* ft. drawdown after *1 1/2* hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well *10* inches.
Depth drilled *180* ft. Depth of completed well *180* ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<i>Sand & Gravel</i>	<i>65</i>	<i>92</i>
<i>Clay (yellow)</i>	<i>92</i>	<i>99</i>
<i>Red Gravel</i>	<i>99</i>	<i>121</i>
<i>Clay Blue</i>	<i>121</i>	<i>168</i>
<i>Washed gravel</i>	<i>168</i>	<i>180</i>
<i>Clay</i>	<i>180</i>	

Work started 19 Completed 19

(13) PUMP: Manufacturer's Name *Byron Jackson*
Type: *Starbuck* H.P. *15*

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME *Lawrence M. Bide*
(Person, firm, or corporation) (Type or print)
Address *Rt. 2 Box 154 Milton-Freewater*
Driller's well number
[Signed] *Lawrence M. Bide*
(Well Driller)
License No. Date *March 18*, 19-*59*