

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

RECEIVED
 JUN 23 1965
WATER WELL REPORT
 STATE ENGINEER
 SALEM, OREGON

UMAT
 4332

State Well No. 6N/35-21A
 State Permit No. _____

(1) OWNER:

Name R.G. RENCKEN
 Address RT # 2 Box 193
MILTON - FREEWATER, ORE.

(2) LOCATION OF WELL:

County UMATILLA Driller's well number 6-12-65
NE 1/4 NE 1/4 Section 21 T. 6N R. 35 E W.M.
 Bearing and distance from section or subdivision corner
625 FEET SOUTH AND 40 FEET WEST
OF THE N.E. CORNER OF SECTION 21

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 84 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used ACE, TORCH
 Size of perforations 1/4 in. by 12 in.
108 perforations from 54 ft. to 80 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 _____ in. Slot size _____ Set from _____ ft. to _____ ft.
 _____ Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & BENTONITE
 Depth of seal 20 ft. Was a packer used? NO
 Diameter of well bore to bottom of seal 12 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusuable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 32 1/2 ft. below land surface Date 6/10/65
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? YAGER
 Yield: 151 gal./min. with 8 1/2 ft. drawdown after 1 hrs.
 " 239 " " 22 1/2 " " 2 "
 " 260 " " 24 1/2 " " 4 "
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"
 Depth drilled 163 ft. Depth of completed well 163 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SOIL	0	8
CLAY BROWN HARD	8	22
GRAVEL MED (AVING)	22	65
BAILIED WELL DRY		
100 gal of WATER		
GRAVEL MED CEMENTED	65	93
PICKED UP WATER TO DRILL WITH AT 70-80		
GRAVEL SMALL CEMENTED	93	163
WATER BEARING 93-TO 150 FEET		

Work started 5/29 1965 Completed 6/12 1965
 Date well drilling machine moved off of well 6/14 1965

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME YAGER Drilling Co.
 (Person, firm or corporation) (Type or print)
 Address RT 3 Box 347-D Waha Waha WASH.
 Drilling Machine Operator's License No. 32
 [Signed] Narold Yager
 (Water Well Contractor)
 Contractor's License No. 155 Date June 21, 1965