NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
OCT 20 1975
WATER RESOURCES DEPT.
SALEM, OREGON

UMAT 4365

State Well No. 6N/35E-22
State Permit No.

(1) OWNER:
Name Glenn L. Parr
Address Rt. 3, Box 71, Milton-Freewater, Ore. 97862

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
8" Diam. from 0 ft. to 78 ft. Gage .277
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bail 20 gpm " 7 ft. D.W. 30 Min.
Bailer test 40 gal./min. with 32 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 55 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 20 sacks
Number of sacks of bentonite used in well seal n/a sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Umatilla Driller's well number
¼ ¼ Section 22 T6-N R. 35 W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 80 ft.
Static level 17 ft. below land surface. Date 10/9/75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8-in.
Depth drilled 115 ft. Depth of completed well 115 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top Soil	0	7	
Gravel	7	18	7
Cemented Gravel	18	55	
Brown Clay & Gravel	55	65	
Sand & Gravel	65	70	7
Cemented Gravel	70	80	
Loose Gravel - Some Sand	80	85	17
Brown Clay & Gravel	85	110	
Cemented Gravel	110	115	

Work started Sept. 19 19 75 Completed Oct. 10 19 75
Date well drilling machine moved off of well Oct. 13 19 75

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [illegible] Date Oct. 15, 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 545

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name D. K. "Don" Smith
(Person, firm or corporation) (Type or print)
Address Rt. 1, Box, 116, Milton-Freewater, Ore.
[Signed] D K Smith
(Water Well Contractor)
Contractor's License No. 204 Date Oct. 15, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45050-119