

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

UMAT  
4425

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

RECEIVED  
1967  
STATE ENGINEER

State Well No. 6N/35-23  
State Permit No. 3N1

(1) OWNER:  
Name Thsmond R. Nesum  
Address RT. 3 Bryant Ave Walkerville

(2) LOCATION OF WELL:  
County Umatilla Driller's well number E  
1/4 Section 23 E.T. 6N R. 35 W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal  Irrigation  Stock well  
(5) TYPE OF WELL:  
Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:  
8" Diam. from 0 ft. to 23 ft. Gage 277  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:  
Perforated?  Yes  No  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:  
Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:  
Well seal—Material used in seal Cement  
Depth of seal 18 ft. Was a packer used? no  
Diameter of well bore to bottom of seal 10" x larger  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: worked  
Gravel placed from 18 ft. to 23 ft. planned  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:  
Static level 4. ft. below land surface Date 4/4 67  
Artesian pressure lbs. per square inch Date 67

(11) WELL TESTS:  
Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.

Baller test 30 gal./min. with 2 ft. drawdown after 2 hrs.  
Artesian flow g.p.m. Date  
Temperature of water 51 Was a chemical analysis made?  Yes  No

(12) WELL LOG:  
Diameter of well below casing 8"  
Depth drilled 46 ft. Depth of completed well 45 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Dark soil & some gravel	0	5
Gray cemented gravel	5	14
Brown H.P. sub coarse	14	18
Brown hard pan	18	24
small layer water bearing gravel 3"	24	24-9"
Brown H.P. and cobbles	24"	33
Small layer of gravel	33	
Brown H.P.	33	44
lean gravel water	44	46
Billed hole and lost		
1-75 of hole.		

Work started 3/31/67 19 67 Completed 4/4 19 67  
Date well drilling machine moved off of well 4/5 19 67

(13) PUMP:  
Pump installed at this time  
Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME Rudd W. Davis  
(Person, firm or corporation) (Type or print)  
Address 159 S. Columbia m-f. Ore.  
Drilling Machine Operator's License No. 147  
[Signed] Rudd W. Davis  
(Water Well Contractor)  
Contractor's License No. 159 Date 4/5, 19 67