

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

UMAT  
4548

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

RECEIVED

AUG 23 1973

State Well No.

6N/35E-25

STATE ENGINEER

State Permit No.

SALEM, OREGON

(1) OWNER:

Name John H. McMunn  
Address Route 4 - Box 103  
Milton-Freewater, Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 0 ft. to 69 ft. Gage 280  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?

id: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "

Bailer test 20 gal./min. with 0 ft. drawdown after 1 hrs.

Artesian flow g.p.m.  
Temperature of water 55 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite slurry  
Well sealed from land surface to 39 ft.  
Diameter of well bore to bottom of seal 9 1/2 in.  
Diameter of well bore below seal 9 1/2 in.  
Number of sacks of cement used in well seal sacks  
Number of sacks of bentonite used in well seal 1 1/2 sacks  
Brand name of bentonite Montana  
Number of pounds of bentonite per 100 gallons of water 50 lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number  
1/4 1/4 Section 25 T. 6N R. 35 E.W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 39 ft.  
Static level 40 ft. below land surface. Date 8/1/73  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"  
Depth drilled 69 ft. Depth of completed well 69 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Gray clay	0	2	
Sm. boulders & gray clay	2	19	
Fine gravel	19	21	
Sm. boulders & gray clay	21	31	
Dry medium gravel	31	32	
Sm. boulders & gray clay	32	39	35
Coarse gravel	39	59	40
Medium sand	59	69	40

Work started 7/23 19 73 Completed 8/1 19 73  
Date well drilling machine moved off of well 8/1 19 73

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] E. M. J. Behrens Date 8/21, 19 73  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 124

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name E. M. J. Behrens (Type or print)  
(Person, firm or corporation)

Address P.O. Box 201 - Milton-Freewater, Oreg.

[Signed] E. M. J. Behrens (Water Well Contractor)

Contractor's License No. 229. Date 8/21, 19 73