

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT RECEIVED

6N/35-26 R

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

STATE OF OREGON
 (Please type or print)
 (Do not write above this line)

State Well No. 6N/35-26 R
 State Permit No. UMAT 4658

G-4313

(1) OWNER:

Name Aaron Weis
 Address R 3 Box 265 M.J. Or.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 33 ft. to 94 ft. Gage 277
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
 Type of perforator used Cutting Tool
 Size of perforations 1/4 - 3/8 in. by 8" to 10" in. length
139 perforations from 65 ft. to 94 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 47 ft. below land surface Date 3/9/68
 Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 72 gal./min. with 70 ft. drawdown after 1/2 hrs.
"Will be pumped at "4. lake"
"date 700 Weis will pump"
 Bailor test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 49 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement
 Depth of seal 50 ft.
 Diameter of well bore to bottom of seal 4 1/2 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Umatilla Driller's well number _____
 1/4 1/4 Section 260 T. 611 R. 35 W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 8"
 Depth drilled 109 ft. Depth of completed well 108 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown Hardpan water bearing gravel	50	63 1/2	W.
Cambridge gr. clay	63 1/2	74	W
Water bearing gravel	74	76	W.
Brown Ag. Agr.	75	91	
Water bearing gravel	91	94	W
Brown Clay & loess gr.	94	109	W
More water gravel at 109			
Drill cutting gravel started coming in			
rolled back for one ft.			
the signal its drilling			

Work started 3/6 19 68 Completed 3/9 19 68

Date well drilling machine moved off of well 3/12 19 68

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Rudd W. Davis Date 3/12, 19 68
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 147

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Rudd W. Davis (Type or print)

Address Rt. 1 Box 162 M.J. Or.

[Signed] Rudd W. Davis (Water Well Contractor)

Contractor's License No. 159 Date 3/12, 19 68