STATE ENGINEER Salem, Oregon



Well Record

STATE WELL NO. 6N/35 - 26A
COUNTY UMATILIA
APPLICATION NO. GR-1966

OWNER: Claude E. Anderson	MAILING	Rt. 3, Box 229	
	CITY AND	•	
LOCATION OF WELL: Owner's No		Milton-Freewater, Oregon	n
NE 14 NE 14 Sec. 26 T. 6 N. R. 35 W.	, W.M.	,	
Bearing and distance from section or subdivision			
corner 400' W. & 910' S.			1

			1
Altitude at well	naumusukka-4		-
TYPE OF WELL: Dug & Drilled Constructed			
		Carthan	J
Depth drilled 54.4 Depth cased 18 = 3	2	Section	
CASING RECORD:			
6-inch			
8-inch			
FINISH:			
FINISH: AQUIFERS:			
AQUIFERS: No information			
AQUIFERS: No information			
AQUIFERS: No information WATER LEVEL: 10-feet			
AQUIFERS: No information WATER LEVEL: 10-feet	ntrifugal	H.P.	3
AQUIFERS: No information WATER LEVEL: 10-feet PUMPING EQUIPMENT: Type Delayal Cer Capacity 275 G.P.M.	ntrifugal	H.P.	3
AQUIFERS: No information WATER LEVEL: 10-feet PUMPING EQUIPMENT: Type Delayal Cer Capacity 275 G.P.M. WELL TESTS:			
No information WATER LEVEL: 10-feet PUMPING EQUIPMENT: Type Delayal Cor Capacity 275 G.P.M. WELL TESTS: Drawdown 10 ft. after	hours	Pumping 275	G.F
No information WATER LEVEL: 10-feet PUMPING EQUIPMENT: Type Delayal Cer Capacity 275 G.P.M. WELL TESTS: Drawdown 10 ft. after Drawdown ft. after	hours	Pumping 275	G.F
No information WATER LEVEL: 10-feet PUMPING EQUIPMENT: Type Delayal Cer Capacity 275 G.P.M. WELL TESTS: Drawdown 10 ft. after Drawdown ft. after USE OF WATER Irrigation	hours	Pumping 275	G.F
No information WATER LEVEL: 10-feet PUMPING EQUIPMENT: Type Delayal Cer Capacity 275 G.P.M. WELL TESTS: Drawdown 10 ft. after Drawdown ft. after USE OF WATER Irrigation SOURCE OF INFORMATION GR-1894	hours	Pumping 275	G.F , 19.
No information WATER LEVEL: 10-feet PUMPING EQUIPMENT: Type Delayal Cer Capacity 275 G.P.M. WELL TESTS: Drawdown 10 ft. after Drawdown ft. after USE OF WATER Irrigation SOURCE OF INFORMATION GR-1894	hours	Pumping 275	G.I