NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENTUMA SALEM, OREGON 97310 within 30 days from the of well completion.

## WATER WELL REPORT E CEIVED on No. CAN 32-37 dd

(Please type or print)

(Do not write above this line)

DEC 151978 tate Permit No. ...

	41144
(1) OWNER:	(10) LOCATION OF WELL:
Name Robort Fellows	County Umafilla Driller's well number
Address R+44 Box 171	SE 45E 4 Section 27 T. 6N R. 35 EW.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
	-
New Well Deepening ☐ Reconditioning ☐ Abandon ☐ If abandonment, describe material and procedure in Item 12.	
	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found & O ft.
Rotary Driven Domestic Industrial Municipal Domestic	Static level 5 3 ft. below land surface. Date 12-5-77
Dug 🛅 Bored 🔲   Irrigation 🔭 Test Well 🗆 Other 🖂	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded W. Welded W. S. "Diam from T. tt to S. 2. ft. Gage 1.250  "Diam from ft. to ft. Gage	(12) WELL LOG: Diameter of well below casing  Depth drilled 200 ft. Depth of completed well 200 ft.  Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated?  Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	Lement GROVEL BROWN 30 97
perforations from ft. to ft	Coment, GROVEL BROWN 30 97 Bowldook GRUY 97 103
perforations from ft. to ft.	Lement Gravel, Brown 103 200
(7) SCREENS: Well screen installed?   Yes No	
Manufacturer's Name	
Type Model No ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Types [] No If yes, by whom? Sange	
Yield: 60 gal./min. with 2/ft. drawdown after / hrs.	
" " "	
" " "	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water 2 Depth artesian flow encountered	Work started // -2 9 - 19 / 7 Completed /2 - 6 - 19 7 ?
(9) CONSTRUCTION:	Date well drilling machine moved off of well 12-7- 1977
(9) CONSTRUCTION:  Well seal-Material used Banton ite Slungy  Well sealed from land surface to 25 ft.	Drilling Machine Operator's Certification:
Well sealed from land surface to 25 ft.	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal	Materials used and information reported above are true to my best knowledge) and belief.
Diameter of well bore below seal	[Signed] [Signed] [Signed] Date 12 -7, 19.77
Number of sacks of comment used in well seal	X // /
How was cement grout placed?	Drilling Machine Operator's License No
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? Yes □ No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water?  Yes No	Name C. W. Surm or corporation) (Type or print)
Type of water? depth of strata	Address 17+43 BOX 143-1-1 20+7. OR
Method of sealing strata off	Ch. U.T.
Was well gravel packed?   Yes No Size of gravel:	[Signed] (Majoral W. Luanna (Water Well Contractor)
Gravel placed fromft.	Contractor's License No. 575 Date 12-7 1977
4,6	1 Dancound troopsing Dave to be and the contraction of the first