

UMAT 472

UMAT 472

RECEIVED JUN 1 1966

RECEIVED JAN 19 1967

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT JAN 19 1967
STATE OF OREGON (Please type or print)

State Well No. 2N/28-7aad(2)
State Permit No.

(1) OWNER: Larry Hanson
Name Oliver Abney
Address Lind, Washington

(2) LOCATION OF WELL:
County Umatilla Driller's well number
1/4 NE 1/4 Section 7 T. 2N R. 28E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): (5) TYPE OF WELL:
Domestic [] Industrial [] Municipal [] Rotary [] Driven []
Irrigation [X] Test Well [] Other [] Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED: Threaded [] Welded [X]
16" Diam. from 0 ft. to 120 ft. Gage 330

(7) PERFORATIONS: Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal puddle clay
Depth of seal 1.30 ft. Was a packer used? no
Diameter of well bore to bottom of seal 1.8 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 90 ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.

(12) WELL LOG: Diameter of well below casing 16"

Depth drilled 157ft. Depth of completed well 155ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include Soil Sandy, Gravel Sandy, Clay Brown, Clay Blue, Clay White, Clay Red, Clay Blue, Green Sand Boulders (hard), Gray Sand Boulders (hard). Includes handwritten note: SEE DEEPENING 7-25-68

Work started Feb. 28 1966 Completed May 6 1966
Date well drilling machine moved off of well May 7 1966

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Ben Dreyer Drilling Contractor
Address Rt. 1, Box 225, Hermiston, Oregon
Drilling Machine Operator's License No. 7
[Signed] Ben Dreyer (Water Well Contractor)
Contractor's License No. 12 Date May 8, 1966

no pump test. see letter in folder