

UMAT
4727

WATER WELL REPORT

State Well No. 6N/35-270

STATE OF OREGON
RECEIVED

State Permit No. GR-2560

(1) OWNER:

Name Chris Fugner
Address RFD #2 Box 346 Milton
SALEM, OREGON

JUL 28 1958

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? owner
Yield: 450 gal./min. with 6 ft. drawdown after 24 hrs.

(2) LOCATION OF WELL:

County _____ Owner's number, if any—
S.W. 4 S.E. 4 Section 27 T. 6N. R. 35 E. W.M.
Bearing and distance from section or subdivision corner
80 ft. N. & 25 ft. W. of the S.E.
corner of the S.W. $\frac{1}{4}$ of the S.E. $\frac{1}{4}$
of sec. 27, twp. 6 N., rge. 35 E.

Baller test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 43 $\frac{1}{2}$ ft. to 52 ft. Gage standard
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
SIZE of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 30 ft. below land surface Date July 20
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] Chris Fugner Date _____, 19____
(Owner)

(12) WELL LOG:

Diameter of well 8" inches.

Depth drilled 76 $\frac{1}{2}$ ft. Depth of completed well 120 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>concret rock</u>	<u>43 $\frac{1}{2}$</u>	<u>50</u>
<u>water course</u>	<u>50</u>	<u>54</u>
<u>concret rock cavity</u>	<u>54</u>	<u>64</u>
<u>concret rock shells</u>	<u>64</u>	<u>91</u>
<u>shale cavity</u>		
<u>streak of yellowish clay</u>	<u>91</u>	<u>93</u>
<u>concret rock brown</u>	<u>93</u>	<u>120</u>

Work started April 3 1951 Completed April 11 1958

(13) PUMP:

Manufacturer's Name Peerless
Type: Turbine H.P. 7 $\frac{1}{2}$

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E. A. G. Shortridge
(Person, firm, or corporation) (Type or print)

Address 193 BOX 348 MILTON-FREEWATER

Driller's well number _____

[Signed] E. A. G. Shortridge
(Well Driller)

License No. 156 Date July 20, 1958