WATER WELL REPORT STATE OF OREGON

RECEIVED

MAR 16 1981

WATER RESOURCES DEPT

State Well No. 6N/35E-28 db State Permit No.

SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name L. T. Hopkins	County // Mali La Driller's well number
Address 926. 61/mpia Onive	NW. 4 SE 4 Section 28 T. 6 N R. 35 F W.M.
City Walla Walla 99362 State Wall	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: 803 3 1332 West 6436
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	Corner Course /4 connen of Scc 28
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 35 ft.
	Static level 5.2 ft. below land surface. Date Make,
Rotary Air	Artesian pressure lbs. per square inch. Date
Cable 🖼 Bored 🗆 Thermal: Withdrawal 🗆 Reinjection 🗆	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilledft. Depth of completed well ft.
Threaded Welded	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry
"Diam from Oft to 82 St. Gauge 250	for each change of formation. Report each change in position of Static Water Level
"Diam fromft. Gaugeft. Gauge	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
ft. To ft. Gauge	Top soil + Brown slay 0 10
(6) PERFORATIONS: Perforated? Fres. No	Cement Syrvel Brown 10 35
Type of perforator used Acetylene	Med tine bravel
Size of perforations of g in. by g in.	with Rrown clay 35 72 22
perforations from	Clay Brown 75 76
75 perforations from . 3.0 ft. to 7.0 ft.	Med Gravel cleaner 130 146 22
perforations from ft. to ft.	Cement Gravel Cleaner 130 146 22
(7) SCREENS: Well screen installed? Yes PNo	Cement bravet brown 146 181 22
Manufacturer's Name	
Type Model No	
Diam. Slot Size Set from ft. to ft.	, -s.
Diam. Slot Size Set from ft. to ft.	
WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☑ Yes ☐ No If yes, by whom? 265	
Yield: 80 gal./min. with 120t. drawdown after 6 hrs.	
11 11 11 11	No.
test gal./min. with drill stem at ft. hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
Temperature of water 59 Depth artesian flow encountered ft.	Work started Rep. 4 19 81 Completed March 519 81
(9) CONSTRUCTION: Special standards: Yes No 🗆	Date well drilling machine moved off of well Much, 9 19 81
Well seal—Material used	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	[Signed] Lowell M. Medelt Date March 59 81
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No.
How was cement grout placed?	Woton Well Contractor's Contist at
The state of the s	Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to
Was pump installed? Type HP Depth ft.	the best of my knowledge and belief.
Was a drive shoe used? \(\text{Yes} \text{No} \text{Plugs} Size: location ft.	Name Lowel W. Mailer T
Did any strata contain unusable water? 🔲 Yes 💆 No	Address RTT Box 140 B M R OFE
Type of Water? depth of strata	The sol M. All lock
Method of sealing strata off	(Water Well Contractor)
Was well gravel packed? ☐ Yes PNo Size of gravel:	Contractor's License No. 265 Date MAACL 12 1981
Gravel placed from ft. to ft.	