

RECEIVED
APR 14 1961

UMAT
4804

G-5525

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER WATER WELL REPORT
STATE OF OREGON

State Well No. 64/35-296

State Permit No.

(1) OWNER:

Name Orvis W. Johnson
Address Rt 2 Box 303
Milton Free Water, Ore.

(2) LOCATION OF WELL:

County Wingetilla Owner's number, if any—
SW 1/4 NE 1/4 Section 29 T. 6 N R. 35 E W.M.
Bearing and distance from section or subdivision corner
56 ft S and 108 ft W of
the SW 1/4 of NE 1/4 of Sec. 29,
T 6 N R 35 E W.M.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 57 1/2 ft. Gage S/16
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used
SIZE of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
..... Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 4.3 ft. below land surface Date March 30
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Orvis W. Johnson Date 31 Mar 1961
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
" " " " "
Bailer test 60 gal./min. with 15 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.

Depth drilled 88 ft. Depth of completed well 88 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil + some Gravel	0	3
Gravel with mixed clay	3	20
Cement Gravel	20	53
Black sand Med. coarse Some water 13" static.	53	55
Cement Gravel	55	70
Water Bearing Gravel Coarse	70	78
Gravel with mixed clay Brown	78	88

Work started March 15 1961 Completed Mar. 29 1961

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Lowell W. Marlatt
(Person, firm, or corporation) (Type or print)

Address Rt #2 Box 1119 Milton Free Water, Ore

Driller's well number

[Signed] Lowell W. Marlatt
(Well Driller)

License No. 265 Date March 30 1961