

RECEIVED

APR 18 1963

WATER WELL REPORT

UMAT
4839

J-2600
64/35-30E

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER STATE OF OREGON

State Well No.

State Permit No.

(1) OWNER:

Name J.E. Elkington
Address Milton-Freewater, Ore. R. 2. bx. 90

(2) LOCATION OF WELL: Well # 3.

County Umatilla Owner's number, if any—
SW 1/4 NW 1/4 Section 30 T. 6 N. R. 35 E. W.M.
Bearing and distance from section or subdivision corner

466 ft. South and 163 ft East from the
Northwest corner of the Southwest
Quarter of the Northwest quarter of
Sec. 30, Tp., 6 N. R. 35 E. W.M.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
....." Diam. from ft. to 137 ft. Gage
....." Diam. from 0 ft. to 43 ft. Gage
....." Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

SIZE of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
..... Slot size Set from ft. to ft.
..... Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No. To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 40 ft. below land surface Date 3/15/55
Artesian pressure NONE lbs. per square inch Date

Log Accepted by:

[Signed] J.E. Elkington Date April 16, 1963
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Null

Was a pump test made? Yes No If yes, by whom Everetti

Yield: 70 gal./min. with ft. drawdown after hrs.
April 1963 yields 88 gal per M.

Baller test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8" inches.

Depth drilled 137 ft. Depth of completed well 137 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Cobble stone	1'	36'
Cement Gravel	36'	75'
Gravel	75'	80'
Cement gravel	80'	84'
Gravel	84'	87'
Cement gravel	87'	115'
Some gravel	115'	123'
Cement gravel	123'	137'

Work started 19 .. Completed April 4, 1955

(13) PUMP:

Manufacturer's Name A.C. Smith Incp.
Type: Turbin H.P. 7.6

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

I have drillers log but unable to find

NAME (Person, firm, or corporation) (Type or print)

Address Driller.

Driller's well number

[Signed] (Well Driller)

License No. Date 19.....