

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON

within 30 days from the date of well completion.

DEC 15 1978

(Please type or print)

(Do not write above this line)

State Well No. 6N/35E-3366

State Permit No.

WATER RESOURCES DEPT.

UMAT 4884

(1) OWNER:

SALEM, OREGON

Name CHARLES FRY
Address 3032 SW HAILEY
PENDLETON, ORE. 97804

(2) TYPE OF WORK (check):

New Well [checked] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [checked] Cable [] Dug [] Driven [] Jetted [] Bored []

(4) PROPOSED USE (check):

Domestic [checked] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded [checked]
8" Diam. from 12 ft. to 18 ft. Gage 250
6" Diam. from 5 ft. to 65 ft. Gage 250

PERFORATIONS:

Perforated? [checked] Yes [] No

Type of perforator used

Size of perforations 1/2 in. by 8 in.
50 perforations from 65 ft. to 40 ft.

(7) SCREENS:

Well screen installed? [] Yes [checked] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [checked] Yes [] No If yes, by whom? DRILLER
Yield: 50 gal./min. with 31 ft. drawdown after 1 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 55° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used PORTLAND CEMENT
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 12 1/4 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 9 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [checked] Yes [] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [checked] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [checked] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County UMATILLA Driller's well number
NW 1/4 NW 1/4 Section 33 T. 6N R. 35E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 33 ft.
Static level 18 ft. below land surface. Date 12-2-78
Artesian pressure lbs. per square inch. Date 12-2-78

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 65 ft. Depth of completed well 65 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include SOIL, GRAVEL, GRAVEL w/H2O.

Work started 12-1 1978 Completed 12-2 1978
Date well drilling machine moved off of well 12-2 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Warren Steinfeld Date 12-2, 1978
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1299

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Gary Burd Well Drilling
(Person, firm or corporation) (Type or print)
Address Pendleton ore
[Signed] Gary Burd
(Water Well Contractor)
Contractor's License No. 544 Date 12-2, 1978