

RECEIVED
 SEP 9 1960
 STATE ENGINEER

UMAT
 4897
 61440

6N/35-33J(1)

File Original and
 First Copy with the
 STATE ENGINEER,
 SALEM, OREGON

WATER WELL REPORT
 STATE OF OREGON

State Well No. _____
 State Permit No. _____

(1) OWNER:
 Name Claude and Elsie McElrath.
 Address Milton-Freewater, Oregon

(2) LOCATION OF WELL:
 County Umatilla Owner's number, if any—
N E 1/4 S E 1/4 Section T. 6 N. R. 35 E. W.M.
 Bearing and distance from section or subdivision corner
A point 693 ft. North from a point 799
feet West from the SE cor of the NE 1/4
of the SE 1/4 of Sec. 33, Tp. 6 N. R. 35 E. W.

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
 Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:
 Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED: Threaded Welded
10" Diam. from 1 plus ft. to 78 ft. Gage Std Line Pipe
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used _____
 SIZE of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 _____ m. Slot size _____ Set from _____ ft. to _____ ft.
 _____ m. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Was a surface seal provided? Yes No To what depth? _____ ft.
 Material used in seal—
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:
 Static level 52 ft. below land surface Date 4/1/53
 Artesian pressure _____ lbs. per square inch Date _____
 Log Accepted by: _____
 [Signed] _____ Date _____, 19____
 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? Moore & Anderson
 Yield: 70 g/gal. min. with 43 ft. drawdown after 4 hrs.
 " " " "
 " " " "
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date 4/1/53
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 10 inches.
 Depth drilled 150 ft. Depth of completed well 150 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Dirt	0	3'
Dirt & rock	3'	7'
River rock	7	11'
Loose gravel	11	32
Cement gravel	32	50
Gravel (water)	50	120
Cement Gravel	120	150

Work started 3:27 1953 Completed 4/1/ 1953

(13) PUMP: Manufacturer's Name Jolieton Bowls
 Type: Turbine H.P. 5

Well Driller's Statement:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Moore & Anderson
 (Person, firm, or corporation) (Type or print)
 Address P. O. Box 136 Walla Walla, Wash.
 Driller's well number _____
 [Signed] [Signature] (Well Driller)
 License No. 205 Date (9/7/60), 19____