

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

see Sp/Std letter 4-9-69 USB.

MAR 28 1969

STATE OF OREGON
WATER WELL REPORT
UMAT
493
STATE PERMIT NO. G-4840

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

State Well No. 2N/30-10 bcc
State Permit No.

(1) OWNER:
Name Elaine Porter Ross
Address 5157 E. 37th
Pendleton Oregon 97801

(11) LOCATION OF WELL:
County Umatilla Driller's well number
1/4 1/4 Section 10 T. 2N R. 30E, W.M.
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

(12) WELL LOG: Diameter of well below casing 8" to 160'
Depth drilled 173 ft. Depth of completed well 173 ft.
Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

CASING INSTALLED: Threaded Welded
8" Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

MATERIAL	From	To	SWL
Topsoil	0	5	
Clay	5	15	
Rock, black	15	35	
Rock, dark brown mixed w/ clay	35	44	
Rock, black	44	120	
Rock, w/ artesian water	120	132	
Rock, black - water bearing	132	160	
Rock, grey - water bearing artesian	160	173	

PERFORATIONS: Perforated? Yes No.
Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.
Static level Surface ft. below land surface Date 3-24-69
Artesian pressure 3 lbs. per square inch Date 3-26-69

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
400 " " " " " " "
Packer test 600 gal./min. with 60 ft. drawdown after hrs.
Artesian flow 200 g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:
Well seal—Material used Puddled clay to pure 5' cement
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 1.0 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

Work started 3-21 1969 Completed 3-24 1969
Date well drilling machine moved off of well 3-25 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Troy Griffin Date 3-26, 1969
(Drilling Machine Operator)
Drilling Machine Operator's License No. 15

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME TROY GRIFFIN (Type or print)
Address 925 HERMISTON AVE., HERMISTON, OREG
[Signed] Troy Griffin (Water Well Contractor)
Contractor's License No. 65 Date 3-26, 1969